

Warsaw University of Technology

FACULTY OF
POWER AND AERONAUTICAL ENGINEERING



Institute of Heat Engineering

Master's diploma thesis

in the field of study Power Engineering
and specialisation Power Engineering

Design and Analysis of the Possibility of Building a Photovoltaic Farm for
University Campus in Adana

Süreyya Algan

student record book number 302364

thesis supervisor
Dr Inż. Marcin WOŁOWICZ

Warsaw, 2020

Abstract

Title: Design and Analysis of the Possibility of Building a Photovoltaic Farm for the University Campus in Adana.

Mankind has always been needed energy from its first existence to the present time. At the beginning, the energy required only as heat source. But in time, the use of energy has turned to be demand as mechanical and then electrical energy.

Last two decades, fossil fuels are identified by communities as; Limited reserves, economical fluctuations on its price and its damage to the environment. These are enough to search for alternative energy sources rather than conventional fossil fuel powered energy sources. Furthermore, transportation problems and foreign source dependency of conventional energy sources has led to preference of renewable energy sources. Therefore, in the recent decade developing countries has been trying to increase the share of renewable energy among its energy production capacities in order to ensure their energy independency. Turkey has high dependence on imported fossil fuels because of energy production systems rely on fossil fuels mostly. But also, the country has high potential for solar energy generation due to its geographical location. Turkey is planning to use solar energy generation potential for evaluate of power generation and country's independence purposes.

In this Thesis, it is planned to be built 9.5 MW PV system in province of Turkey, Adana and design and feasibility analysis carried out for this system for either meet the demand of the university's electricity consumption and sell the overproduction to the grid for payback of the budget of the system.

Keywords: Renewable Energy, Solar Energy, PV technology, PV system, Solar power generation system, Feasibility of PV system, Design of PV system.



Streszczenie

Tytuł: Projekt i analiza możliwości budowy farmy fotowoltaicznej dla kampusu uniwersyteckiego w Adanie.

Ludzkość potrzebowała energii od początku istnienia do chwili obecnej. Na początku, energia potrzebna była tylko jako źródło ciepła. Jednak z czasem zużycie energii stało się popytem na energię mechaniczną, a następnie elektryczną.

W ostatnich dwóch dekadach, społeczności z ograniczonymi rezerwami oraz ekonomicznymi wahaniami wychwytyją ceny oraz szkody dla środowiska powodowane przez paliwa kopalniane. To są wystarczające powody dla szukania alternatywnych źródeł energii zamiast konwencjonalnych źródeł energii zasilanych paliwami kopalnianymi. Ponadto problemy transportowe i zależność od konwencjonalnych źródeł energii od zagranicznych źródeł doprowadziły do preferowania odnawialnych źródeł energii. Dlatego w ostatnim dziesięcioleciu, kraje rozwijające się starają się zwiększyć udział energii odnawialnej w swoich zdolnościach wytwarzania energii, aby zapewnić sobie niezależność energetyczną. Turcja jest w dużym stopniu uzależniona od importowanych paliw kopalnianych, ponieważ systemy produkcji energii opierają się głównie na paliwach kopalnianych. Ten kraj ma również duży potencjał do wytwarzania energii słonecznej ze względu na swoje położenie geograficzne. Turcja planuje wykorzystać ten potencjał generowania energii słonecznej do oceny wytwarzania energii oraz do uzyskania więcej niezależności.

W niniejszej pracy, planuje się budowę systemu fotowoltaicznego o mocy 9,5 MW w prowincji Tureckiej Adana oraz przeprowadzenie analizy projektu i wykonalności tego systemu w celu zaspokojenia zapotrzebowania na energię elektryczną uniwersytetu i sprzedaży nadprodukcji do sieci w celu zwrotu budżetu systemu.

Słowa kluczowe: Energia Odnawialna, Energia Słoneczna, Technologia PV, System PV, System Wytwarzania Energii Słonecznej, Wykonalność Systemu PV, Projekt Systemu PV.



Statement of the author (authors) of the thesis

Being aware of my legal responsibility, I certify that this diploma:

- has been written by me alone and does not contain any content obtained in a manner inconsistent with the applicable rules,
- had not been previously subject to the procedures for obtaining professional title or degree at the university

Furthermore I declare that this version of the diploma thesis is identical with the electronic version attached.

.....	
date	author's (s') signature

Statement

I agree / do not agree^{*1} to make my diploma thesis available to people, who may be interested in it. Access to the thesis will be possible in the premises of faculty library. The thesis availability acceptance does not imply the acceptance of making the copy of it in whole or in parts.

Regardless the lack of agreement the thesis can be viewed by:

- the authorities of Warsaw University of Technology
- Members of The Polish Accreditation Committee
- State officers and other persons entitled, under the relevant laws in force in the Polish Republic, to free access to materials protected by international copyright laws.

Lack of consent does not preclude the control of the thesis by anti-plagiarism system.

.....	
date	author's (s') signature



Acknowledgments

I am extremely grateful to advisor of this thesis Dr. Marcin Wołowicz for all his guidance throughout the thesis and trust for this study being my own work.

I also would like to thank, Adana Alparslan Türkeş Science and Technology University's head of Directorate of Construction and Technical Works who is İsmail A. Şahin for sharing University's data , Emre Üçkardes for sharing his knowledge and ADAME company for budget instructions regarding the topic of this thesis.

The biggest thanks go to my mother who is Prof.Dr. Nese Yavuz Algan for being there for me with materially and spiritually in every phase of my educational life.

I am sending gratitude and love to my family and beloved ones who trusted on and stood by me every phase of my life.

Warsaw, 2020



Table of Contents

INTRODUCTION	1
CHAPTER 1: TURKEY	3
1.1. Turkey: An overview.....	3
1.1.1. Mediterranean Region of Turkey.	3
1.1.2. Geography of Mediterranean Region of Turkey.	4
1.1.3. Climate of Mediterranean Region of Turkey.....	4
1.1.3.1. Adana: an overview.....	4
1.1.3.2. Geography of Adana.....	4
1.1.3.3. Climate of Adana	5
CHAPTER 2: SOLAR ENERGY IN TURKEY	6
2.1. Approach to Solar Electricity Generation in Turkey	6
2.2. Turkey's Solar Energy Potential.....	6
2.3. Primary Energy Sources and Solar Utilization	7
CHAPTER 3: SOLAR ENERGY	10
3.1. Solar Energy.....	10
3.2. Electricity Generation Technologies from Solar Energy.....	14
3.2.1. Photovoltaic Technology	14
3.2.2. History of PV evolution.....	15
3.2.3. Working Principle of Solar Cells	15
3.2.4. Photovoltaic Solar Panels According to Production Type and Structure	20
3.2.4.1. Crystalline Silicon Cells	20
3.2.4.1.1. Monocrystalline Silicon Cells.....	21
3.2.4.1.2. Polycrystalline Silicon Cells.....	21
3.2.4.1.3. Thin Film Cells	22
3.2.5. Solar Photovoltaic System Components	22
3.2.5.1. Solar Photovoltaic Modules	23
3.2.5.2. Array Mounting Racks	23
3.2.5.3. Inverter	25
3.2.5.4. Grounding Equipment	26
3.2.5.5. Combiner Box	27
3.2.5.6. Surge Protection.....	27
3.2.5.7. Disconnects	27
3.2.5.8. Charge Controller	28
3.2.5.9. Solar Energy System Cables.....	28

3.2.5.10. Battery	29
3.2.6. Photovoltaic Systems by Usage.....	29
3.2.6.1. Grid Independent Systems (off-grid).....	29
3.2.6.2. Grid Connected Systems (on-grid)	30
4. CHAPTER 4: CASE STUDY	32
4.3. Solar Radiation	33
4.5. Energy Analysis and Production of The Solar Power Plant	38
4.6. Layout Design of Modules.....	41
4.7. Economic Analysis of the Solar Power Plant	43
4.7.1. General	43
4.7.3. Projected Annual Fixed Expenses.....	43
4.7.4. Unit Prices Used in the Project.....	44
4.7.5. Consumption and Production Balance.....	46
4.7.7. Economical View for 10 Years	53
4.7.8. Setup Process and Budget Analysis.....	54
4.7.9. Payback time	55
CONCLUSION.....	56
REFERENCES	59
Acronyms and Abbreviations	63
List of Figures	66
List of Tables.....	68
List of Appendices	70



INTRODUCTION

Energy, which is defined as one of the main factors for the survival of humanity. With the developing technology, energy, which has an ever-increasing effect on our daily lives, has become an indispensable concept. In the simplest terms, energy is needed in every area, from transportation to heating, lighting to communication and for operation of the devices we do our ordinary work. While our connection with energy is so strong and there is an ever-increasing demand, energy sector has shown a significant change and development from past to present.

After the 1973 petroleum crisis, the importance of the energy came to be the most important topic all around the world. Countries were to be afraid of come around of such a crisis and to stay away from problem in energy security, they set off on a quest of alternative energy sources. Renewable energy sources are chosen as a best alternative of fossil fuels. However, researches and developments had started in earliest 20th century due to the easy accessibility, way of use and its low-cost unit by produced energy of fossil fuels, there was no need to use of renewable energy sources. But also, with the help of present technological developments and continuous bad intention use of the fossil fuels with politics are accelerated the demand of renewables since 2000s.

In order to respond to the increasing energy demand in our country, the current resources should be used effectively. In this direction, many studies are carried out to use renewable energy sources. Due to its geographical location, there is a high potential for solar energy in our country. Especially with this method, electricity generation is increasing day by day. The installation of photovoltaic systems, which do not produce waste during electricity generation. Because of its simple usage and maintain installation of photovoltaic systems is becoming widespread in Turkey.

Within the scope of this thesis, solar power generation system is designed and analyzed and after this step, its feasibility analysis is carried out. Main purpose is to meet the electricity consumption and payback itself as soon as possible. But also, trying to decrease the carbon footprint and set the university good example and encourage the other universities for such an investment.

This Thesis consist of four main chapters. In the first chapter includes not only the basic overview of the country but also covers the brief information about such as climate and geography of the region that system planned to be built at. After the first chapter, at the second chapter Turkey's solar energy generation approach and solar energy potential has mentioned. But also, this chapter has touched briefly on the Turkey's primary energy sources and solar utilization. The third chapter covers the information about solar energy, PV technology, working principles and related components to build a solar power generation system. In the fourth

chapter which is last chapter of the thesis, design and detailed feasibility analysis carried out and concluded with the help of CAD and HELIOSCOPE simulation software.



CHAPTER 1: TURKEY

1.1. Turkey: An Overview.

Turkey, officially the Republic of Turkey is a transcontinental country located on the Anatolian peninsula, with a smaller portion in Southeast Europe. The part of Turkey in Europe, is separated from Anatolia by the Sea of Marmara, the Bosphorous and the Dardanelles. Turkey is bordered by Greece and Bulgaria to its northwest, the Black Sea to its north, Georgia to its northeast, Armenia, the Azerbaijani exclave of Nakhichevan and Iran to its east, Iraq and Syria to its southeast, the Mediterranean Sea to its south, and the Aegean Sea to its west. Istanbul is the largest city in the country while Ankara is the capital. Approximately 70 to 80 per cent of the country's citizens identify as Turkish, while Kurds are the largest minority at anywhere from 15 to 20 percent of the population. ^[1]

1.1.1. Mediterranean Region of Turkey.

Mediterranean region takes its name from the Mediterranean Sea and occupies 15% of the total land of Turkey with its 120.000 square kilometers . The population is mostly concentrated at the locations suitable for tourism, industry, agriculture and commerce. Provinces in this region: Antalya, Adana, Mersin, Hatay, Isparta, Burdur, Kahramanmaras, Osmaniye. ^[3]



Figure 1 : Mediterranean Region of Turkey.^[3]

1.1.2. Geography of Mediterranean Region of Turkey.

Mediterranean Region is a mountainous region. Taurus Mountains, which is a mountain chain, covers most of the mediterranean region. Another mountain chain is called Amanos Mountains which is at the east of the region. The mountains run in parallel to sea and in almost every places. The coastal areas were formed in the lower courses of the rivers. The most important coastal area is Çukurova in the eastern part of the mediterranean region. It was formed by three rivers, Berdan, Seyhan and Ceyhan. Main lakes of the region, like Lake Beyşehir, Lake Eğirdir and Lake Burdur which are in the north west of this region.^[2]

The plains of this region are extremely rich for agricultural. Fertile soils and suitable climate make the area suitable for growing grapes and citrus fruits and in irrigated areas cotton and rice. Droughts are not uncommon, and Summers are hot. Other industrial and agricultural products of the area are aluminum and steel and wheat, tobacco, green houses, barley. 80% of total of Turkey's citrus fruits are grown here, meanwhile anamur bananas are specific only to Mediterranean region.^[3]

1.1.3. Climate of Mediterranean Region of Turkey.

The Mediterranean Region has a Mediterranean climate at the coast, with mild to cool, wet winters and hot, dry summers and a semi-arid continental climate in the interior with cold, snowy winters and hot, dry summers.^[2]

1.1.3.1. Adana: an overview.

Adana is a major city in southern Turkey. The city is populated around the the Seyhan river, which is 35 km inland from the Mediterranean. Adana Province has a population of 1.75 million making it the 5th most populated city in Turkey.^[4]

Adana lies in the heart of Çukurova also as known as Cilicia, a geo-cultural region. Home to six million people, Çukurova is one of the largest population concentrations in Turkey, as well as the most productive area in terms of agriculturally, owing to its large stretch of flat and fertile land [4].

1.1.3.2. Geography of Adana.

Adana is located at the eastern side of the Mediterranean, where it serves as the gateway to the Çukurova plain. This large stretch of flat, fertile area lies southeast of the Taurus Mountains.

From Adana, crossing the Çukurova west direction, the road from Tarsus enters the foothills of the Taurus Mountains, eventually reaching an altitude of almost 1,200 m. It goes through

the famous Cilician Gates, the rocky pass through which armies have coursed since the dawn of history, and continues to the Anatolian plain.

Seyhan reservoir surrounds the north of the city. The Seyhan Dam, that completed in 1956, was constructed for hydroelectric power and for irrigation the lower Çukurova plain. Two irrigation channels in the city flow to the plain, passing through the city center from east to west. There is another canal which is irrigating the Yüreğir plain and to the southeast of the city. The 37th parallel north passes through the city.^[4]

1.1.3.3. Climate of Adana.

Adana has a hot-summer Mediterranean climate under both the Köppen classification, and a dry-hot summer subtropical climate under the Trewartha classification. Winters are mild and wet. Summers are long, hot, humid and dry. The highest recorded temperature was on 8 July 1978 at 45.6 °C and the lowest recorded temperature was –8.1 °C. ^[4]

CHAPTER 2: SOLAR ENERGY IN TURKEY

2.1. Approach to Solar Electricity Generation in Turkey

The rapid economic growth experienced in recent years in Turkey, rapid population growth and rising living standards, has brought a significant increase in energy demand. mostly from fossil energy sources to meet energy demand, Turkey, is largely dependent on external energy sources in terms of primary energy is imported every year, spending billions of dollars. The high utilization of fossil fuels brings with it the problem of foreign dependency in energy and high import costs as well as environmental problems. Energy supply security of energy supply and reduce emissions from its importance in terms of more efficient use of Turkey's renewable energy potential is increasing with each passing year. while offering a high potential of solar energy in renewable resources, be considered as a new resource for meeting Turkey's growing electricity needs is of paramount importance.

2.2. Turkey's Solar Energy Potential

Turkey's current geographic location is very efficient in terms of solar energy potential. According to Turkey's Solar Energy Potential Atlas, total sunshine duration in year is 2.737 hours (daily 7.5 hours), total solar energy in year is 1.527 kWh/m² (daily 4,2 kWh/m²) had been identified.^[5] Turkey's Solar Energy Potential Atlas is given below the figure 2.




Figure 2: Turkey's Solar Energy Potential Atlas. ^[6]

As we can see from the Figure 2 when we go from south side to north side Radiation potential of the sun is gradually decreasing. Due to excess of cloudy and rainy days/seasons also the geographical location of Black Sea region (north side) has the lowest potential of radiation. On the other hand, Part of Aegean region (southwest side), Mediterranean region

(south side), Inner Anatolian region (middle side), East Anatolian (east side) and South East Anatolian region (south east side) has more potential of radiation. To invest Solar Power in these five regions of Turkey is more feasible and paying off in short term When we compare to northern part of Turkey. Sun Radiation of the regions are shown at table 1 which is given below.

Table 1: Solar Energy and Radiation Time for Every Region.^[7]

REGION	TOTAL SOLAR ENERGY (kWh/m ² -year)	SUN RADIATION TIME (hour/year)
South East Anatolia	1.460	2.993
Mediterranean	1.390	2.956
East Anatolia	1.365	2.664
Inner Anatolia	1.314	2.628
Aegean	1.304	2.738
Marmara	1.168	2.409
Black Sea	1.120	1.971

Germany is heading country at solar energy and their higher solar radiation value is 1200 kWh/m² per year. ^[8] This radiation value is approximately the same with the lowest value of the Black Sea Region of Turkey. From this side point of view, we could say that Turkey is not using the benefits of its own advantages for solar energy.

2.3. Primary Energy Sources and Solar Utilization

Primary energy is an energy when used directly without any conversion and includes renewables and non-renewables. Solar, Wind and other known renewable energy sources are primary energy sources. Petrol, Natural Gas, Coal are non-renewable Primary energy sources.

According to Republic of Turkey Ministry of Energy and Natural Resources data balance tables (2018) Turkey's primary energy sources supply is in total 143.666 thousand TOE ^[11] and % 1,13 drop when compared to previous year. Turkey's primary energy sources are gas, oil, coal, lignite, geothermal, hydro, bioenergy, wind, solar and asphaltite figure 3 given below as a pie chart as percentage.




Figure 3: Turkey Distribution of Energy Supply by 2018 Primary Sources. ^[9]




Figure 4: Turkey's Primary Energy Supply Change During the Years. ^[9]

In 2016 the value of 136.228 thousand TOE is announced by the Turkey Ministry of Energy and Natural Resources but after a year Turkey has seen greatest value of the primary energy supply with 145,304.6 thousand TOE. In 2018 This value has decreased to 143.660 thousand TOE. This data shows that Turkey's energy requirement is declined when compared to previous year. When we check the domestic production values in years, 2016 is 35.374 thousand TOE, 2017 is 35.357 Thousand TOE and in 2018 is 39.675 thousand TOE are observed in Republic of Turkey Ministry of Energy and Natural Resources data balance tables. The reason of this domestic production amounts is getting higher year by year is totally connected to use of renewable energy percentage increases in total of production. ^[11]




Figure 5: Use of Solar Energy in Primary Energy Source Change Graph by Years. ^[10]

The use of Solar energy in primary energy source change graph by years is given in figure 5. Especially after 2010 it raised rapidly. Also, the use of solar energy has reached up to 1.547,35 thousand TOE in 2018, this peak values shows that in following years we will come across with more projects in RES and governmental positive regulations for usage of solar energy. Before the 2014, Solar energy had been used for just hot water production for home and Industrial processes such as preheating and dehydration cycles. After 2015, addition to these usages with potential and developing technologies solar energy has started to use for production of electricity. This breakpoint influenced the slightly increased use of solar energy. Government is expecting the sharp increase in this energy sector following years. ^[11]

CHAPTER 3: SOLAR ENERGY

3.1. Solar Energy

As it is known, the solar system is consisting of Sun and the surrounding planets. Sun is the primary also major energy source of this whole as well as for the world. In particular, it is an undeniable fact that the sun is an indispensable resource for living things on Earth. Most of the various energy sources used today are caused or are created by sun. The world can be illuminated with solar energy; water cycle can be provided by precipitation and most importantly, living life can be sustained by photosynthesis. This star (Sun), which is vital for our world, can also help to produce industrial energy.




Figure 6: Sun. ^[17]

The sun is a star with a diameter of 1,400,000 km (approximately 110 times the world's diameter), mass 2×10^{30} kg (approximately 330,000 times the earth mass) and rotates around its own axis. It is known that in the center of the sun, a fusion reaction occurs mainly by the fusion of hydrogen nuclei and the temperature reaches approximately 15-16 million ° C. In this context, it is stated that approximately 90% of the Sun is made up of hydrogen.^[12]

In the core of the sun, hydrogen nuclei are fused to form helium nuclei, resulting in a great energy as a result of this reaction. Since the total radiation of the sun is 3.8×10^{26} J / second, about 600 million tons of protons, i.e. hydrogen, are consumed in the sun in one second. Although this number may seem frightening at first glance, considering that the mass of the Sun and almost 90% of this mass are formed by protons, it turns out that there is a period of

approximately 5 billion years to consume hydrogen fuel in the Sun. In this respect, it is stated that the Sun is an inexhaustible energy source for humanity.^[13]

Solar energy reaching the world comes from a cooler (about 6000 ° K) and a narrow upper region of sun which is several hundred kilometers. This zone consists of low-density ionized gases and is defined as a zone that does not transmit visible light. The atoms in this region radiate in proportion to their temperature and thus cause the radiation of this region.

The Earth is approximately 150 million km away from the Sun. The earth rotates in an elliptical orbit, both around itself and around the Sun. In this respect, the energy coming from the sun to the world changes both on a daily basis and throughout the year. In addition, as the rotational axis of the Earth itself rotates at an angle of 23.5° with the orbital plane around the Sun, the sun intensity falling on the earth changes throughout the year and thus the seasons are formed.

Approximately 4×10^{26} J energy is transmitted to the Earth from the Sun in seconds. This is quite a small value given the total energy emitted by the sun. However, even this amount is approximately 15-16 thousand times the total energy used by mankind in the world today. Solar energy coming to the earth is composed of radiation of various wavelengths and reaches the world by crossing the Sun-Earth in about 8 minutes. The radiation travels at a speed of 300,000 km per second, in other words, at the speed of light.

Solar energy, which comes out of the atmosphere on an area per square meter perpendicular to the sun's rays, is called the Solar Invariable (S) and its value is $S = 1373 \text{ W / m}^2$. This value, by definition, can be taken literally throughout the year. Because the surface perpendicular to the incoming sun rays should always be considered. However, since the Earth's orbit around the Sun is not a circle but an ellipse, there is a 3.3% change in this value throughout the year. 832 W / m² part of this energy reaches the earth due to absorption and reflection events.^[14]

It is calculated that the amount of solar energy reaching the world in approximately one hour is enough to meet the annual global energy demand. However, it can be said that solar energy has not been provided to sufficient use yet due to its low density, interruption and efficiency in current technology. Figure 7 presents a graphical comparison of annual solar energy reaching the world with the amount of energy obtained from other energy sources or other energy types and annual global energy demand.




Figure 7: Global Energy Potential. Comparison of renewable and conventional energy sources. For renewable, the amount of energy is shown per year, while for conventional sources the total reserve is displayed. [15]

It is known that not all of the solar energy falling on earth turns into useful energy. Some of these rays are absorbed by the atmosphere, while others are reflected back from the clouds. Figure 8 shows the distribution of sun rays falling on Earth.




Figure 8 : Distribution of the sun's rays falling on the earth. [16]

While making calculations related to solar energy, it is named in different ways according to the way the solar beam falls on the world. These.

Direct Radiation: This radiation value defines the radiation received directly from the sun. It is especially used in condensed solar energy systems and solar energy heat calculations.

Diffused Radiation: This radiation value is formed by the dispersion of the Sun as it passes through the earth's atmosphere and includes the amount of radiation reflected from the surface and the radiation reflected from the atmosphere.

Global Radiation: It is the sum of direct and diffused radiation and is widely used especially in photovoltaic system calculations.^[18]




Figure 9 : Types of Solar Radiations.^[19]

The biggest energy source of the world is the sun. Solar energy systems are an inexhaustible type of energy that does not give harmful gases to the environment. The use of solar energy provides great advantages since it does not harm the environment, it is an inexhaustible and very cheap energy source. If we list the advantages of solar energy as substances:

- First of all, the sun is an abundant and inexhaustible source of energy.
- It is a clean energy type, it does not pollute the environment, does not have smoke, gas, carbon monoxide, sulfur and radiation.
- It is suitable for local applications. It is possible to utilize solar energy almost everywhere where energy is needed. The energy needs of a clock, a calculator or a lighthouse, a forest watchtower can be met.
- As it is not dependent on the outside, it is far from the possible economic crisis.
- For many applications, complex technology is not required. Operating costs are very low.

In addition to its many advantages, solar energy is available in some limitations. If we list these limitations:

- Since the solar radiation coming to the unit surface is low, a large surface is needed
- Since solar radiation is not continuous, it requires storage. Storage facilities are limited.
- In winter, when the energy need is high, there is little solar radiation and there is no nighttime.
- For the system that makes use of solar radiation to receive sunlight continuously, the environment must be open and not shaded.

3.2. Electricity Generation Technologies from Solar Energy

Technologies used in electricity production from solar energy; It is divided into two main groups: photovoltaic (photovoltaic-PV) and condensed power systems (concentrated solar power-CSP). Detailed information on photovoltaic technology is given below.

3.2.1. Photovoltaic Technology

Photovoltaic (PV) effect; It is the electrical potential formed between the common junction of two different materials exposed to solar radiation. With this effect, the PV cell directly converts light into electricity. This effect was found by the French physicist Becquerel in 1839.[9] Solar cells can be used in any application where electrical energy is required. Solar cell modules depending on the application; They are used in conjunction with accumulators, inverters, battery charge monitoring devices and various electronic support circuits to form a solar cell system (photovoltaic system). These systems are used especially in areas that are far from residential areas, without electricity grids, when it is difficult and expensive to transport fuel to the generator. Apart from that, it is also possible to mix them with diesel generators or other power systems. A photovoltaic system converts solar energy into electrical energy in order to feed the load that operates with direct current (DC) or alternating current (AC). The produced electricity is DC. A direct current load can be fed from here. Since solar radiation is not continuous and stable, there may be situations where the load is insufficient in feeding. In addition, there may be times when the generated energy is more than the system needs.

This excess surplus energy can be stored in the batteries, providing energy for time periods when the solar radiation is insufficient. The load to be operated may be operating with alternating current. In this case, an inverter is used to convert direct current to alternating current. Photovoltaic systems can be built independently from the local electricity grid to feed electrical charges located at distant locations. However, photovoltaic systems located close to the local electricity grid can be arranged to transfer energy to the grid.^[20]

PV system technology is ready for installation as a result of bringing together PV panels and system stabilizers. Depending on the basic material (semiconductor) type and commercial maturity level, PV system technologies are classified into three groups: crystal silicon, thin film and developing new PV technologies.

3.2.2. History of PV evolution

Although solar energy has been used in different ways by human beings for centuries, it is seen that the first studies required to obtain electricity from solar energy started in the middle of the 19th century. For the first time in 1839, French scientist Becquerel found the Photovoltaic phenomenon by observing that the tension between the electrodes immersed in the electrolyte is dependent on the light falling on the electrolyte.^[21] A similar event in solids was firstly made in 1876 on selenium crystals by G.W. Adams and R.E. It is known to be shown by Day. In literature scans, the efficiency of photovoltaic cells was observed to be 1% in 1914. In 1954, it is stated that three American scientists, Chapin, Fueller and Pearson, achieved 6% efficiency value on the silicon solar cell and succeeded in commercializing the conversion from solar to electrical energy.^[22]

In the following years, which was accepted as a turning point for photovoltaic power systems, research and first designs were made for power systems to be used in spacecraft. It is known that photovoltaic power systems have been the reliable source of space studies since the early 1960s.

It is observed that until the early 1970s, the applications of solar panels were limited. Although research and development efforts for the use of solar panels as an electrical power system on earth began in 1954, the real interest occurred in the years following the "first oil crisis" in 1973.

Large-scale and comprehensive research and development projects have been launched in the US, Europe and Japan, but much less semiconductor material is required, and efforts to increase the efficiency of solar panels based on proven silicon crystals in space studies, and therefore Studies on thin film solar panels, which can be produced cheaper, have been accelerated.^[23]

3.2.3. Working Principle of Solar Cells

Semiconductor technology forms the basis of electronics. The most basic electronic materials such as diodes and transistors operate depending on the semiconductor technology. The ability of a material to conduct current is based on electrons located in orbits around the atomic structure of the material. The number of electrons that each orbit can carry is determined by the formula $2n^2$.^[24] According to this, the conductor is called as the conductor

because there is an electron in the last orbit of the copper atom, the semiconductor for the 4 atom electrons in the last orbit of the silicon atom, and the insulator because there are 8 electrons in the last orbit of the neon atom. ^[25]

Figure 10 shows the energy levels of the forbidden band between the conductivity band and the valence band of semiconductor and insulating materials. The smaller the forbidden bandwidth between the conductivity band of the atoms and the valence band, the more conductive it is considered. As this bandwidth increases, it evolves from atomic conductivity to insulating. The forbidden bandwidth of semiconductors is between atoms considered conductive and insulating. ^[24]




Figure 10: Energy Levels of Conductor, Semiconductor and Insulator. ^[26]

Most photovoltaic cells are made of silicon, an element that is at the heart of all modern electronics. Silicon is special because of the arrangement of its electrons it has four out of the possible eight electrons in its outermost shell. This means that it makes perfect covalent bonds with four other silicon atoms, forming a lattice structure. Figure 11 shows Silicon Atom and its chemical structure.




Figure 11: Silicon Atom and its Chemical Structure.^[27]

This bonding mechanism means there are very few free electrons floating about, which is what we need to create electricity. That is what electricity is, after all the flow of electrons. Because of the arrangement of bonds in its crystal structure, silicon in its pure form does not have very many free electrons, so we 'dope' it. ^[27]

In order to make the semiconductor materials to transmit the electric current well, the doping process is done. For the doping process, phosphorus is selected from the 5A group of the periodic table and boron from the 3A group. As shown in figure 12, silicon added with phosphorus selected from 5A group turns into n-type material. Here, it tries to bond with 5 electrons of phosphorus that can bond, with 4 electrons of silicon that can bond. After the mutual bond pairings are established, one electron of phosphorus is exposed and an n-type material is formed, which is rich in electron. As shown in Figure 13, when silicon is added to the boron from the 3A group, as a result of the bonding of mutual electrons, an electron of the silicon stays idle and a part called the cavity is formed opposite the electron it cannot match. This material is called p-type material.




Figure 12: Obtaining n-type material after doping process. ^[27]




Figure 13: Obtaining p-type material after doping process. ^[27]

The extra electrons and holes will float round the lattice; they are 'shared' by all the atoms within the structure. This provides every doped material an overall slight preference to either give or receive electrons. this can be referred to as electronegativity a measure of how powerfully an atom or material hangs on to its electrons.

Through doping, and therefore the resulting changes in electronegativity, silicon is become a conductor of electricity.

However, when we place the p-type and therefore the n-type materials in contact with each other which is shown at figure 14, one thing interesting (and useful) happens. At the purpose wherever the two types meet the junction electrons from the n-type layer diffuse over into the

p-type layer, yield a region with a small positive charge within the n-type layer. The reverse happens within the p-type layer holes diffuse into the n-type layer, yield a small negative charge during a region of the p-type layer. This creates an electrical field, which can direct the flow of electrical current.




Figure 14: Combination of P type and N type material. [27]

When we consider a photovoltaic cell made of a thin combination of p-type silicon arranged over a layer of n-type silicon. once daylight hits our cell, the energy of its photons excites electrons into states known as 'electron-hole pairs'. once these are shaped within the neighborhood of the electrical field at the junction of the p-type and n-type layers, the electrical field pulls the pair apart (they kind a 'charge-separated' state). Controlled by the force of the electrical field, the electrons travel to the n-type side, and the holes to the p-type side.

The photon's energy can even create electron-hole pairs in different components of the doped semiconducting material. Sometimes, these electron-hole pairs can simply pair up once more (recombine) with the additional energy emitted as heat. However, if they notice themselves close to the electrical field at the junction of the p- and n-type layers, the electrical field can send electrons to the n-type layer, and holes to the p-type layer.

If you produce an external association (using electrodes and a wire) between the two layers, the electron can then travel back through the wire to the p-type layer, as an electrical current that will usefully work. the total factor acts rather like an electrical battery, continually recharged by the daylight.




Figure 15 : Presentation of a Solar Cell

3.2.4. Photovoltaic Solar Panels According to Production Type and Structure

FV solar panels can be obtained from different materials and different methods. The variety of methods and raw materials in production depends on technological progress and economic reasons. Solar cells can be categorized as 1st, 2nd and 3rd generation solar cells. First Generation solar cells, also known as conventional solar cells, are silicon-based cells and are called monocrystalline silicon and polycrystalline silicon. These first-generation solar cells are dominantly sold in the market and have a large production area. second Generation solar cells: It is made of materials such as amorphous silicon (a-Si), copper indium gallium selenide (CIGS) and cadmium telluride (CdTe), and is used commercially in solar power plants, small-scale grid-independent systems. Third Generation solar cells are the studies that are carried out with a few thin film technologies, which are not commercially produced but whose R&D studies continue.^[28] Solar cells: crystalline silicon cells, thin film solar cells and other cells are considered in 3 groups.

3.2.4.1. Crystalline Silicon Cells

Crystal silicon cells: It has different types such as monocrystalline silicon, polycrystalline silicon and ribbon silicon. These differences occur again according to the production methods. Silicon-based cells are the most preferred cells in the market because they have been working on for many years and developing in parallel with the microelectronics market. Other reasons why it is common are; it can be counted as being abundant in the world, containing no toxic

substances, being available for many years outside, being able to reach high yields, and lowering production costs.^[29]

3.2.4.1.1. Monocrystalline Silicon Cells

Silicon is one of the most common atoms on earth. Sand and quartz forms are the most common in nature. However, quartz material is more suitable for production since the silicon in sand is quite low. Silicon ratio in quartz is approximately 90% and 99% purity are obtained by certain processes. Silica is processed through several processes.^[30] Monocrystalline silicon cells are the oldest solar cells. It dates to the 1950s and is produced using a method known as the "Czochralski method". In the application of this method, the crystal of the vaccine that is constantly rotating into the high purity molten silicon is immersed and pulled upwards. A nugget with a single crystalline molecule is formed from the molten silicon. These ingots are sliced into sections of approximately 0.5 mm thickness to be very thin. Although monocrystalline silicon cells are more efficient than other silicon cells, they are not so preferred because they have an expensive and complex production process. Their efficiency varies between 15-20%.^[31] Figure 16 which is shown below presents monocrystalline silicon cells.




Figure 16 : Monocrystalline silicon cell example.^[35]

3.2.4.1.2. Polycrystalline Silicon Cells

The increase in the solar panel market has increased the need for cheaper and easier production methods. Polycrystalline silicon cells began to become widespread since the 1980s, when industrialization was accelerating in solar panels. Polycrystalline silicon cells are obtained from pure molten silicon using a casting process. Silicon does not have a homogeneous distribution, as in monocrystals, and therefore their efficiency is lower. It is the most preferred silicone cell type on the market. It is easier to manufacture and more cost

effective. Their efficiency varies between 11-15%.^[32] However, although both cost and efficiency are low, it is preferred due to cost benefit. Figure 17 represents Comparison of crystalline solar cells. The ones on the left are made of polysilicon (poly-Si) while the ones on the right are made of monocrystalline silicon (mono-Si).^[33]




Figure 17: Representations of Polycrystalline Silicon Cells (left side) and Monocrystalline Silicon Cells (right).^[33]

3.2.4.1.3. Thin Film Cells

These cells are formed by coating semiconductor material on materials such as glass and iron with a thickness of 1-2 micrometers. Commercially widely used types include amorphous silicon (a-Si), cadmium telluride (CdTe) and copper indium gallium selenide (CIGS). Although it is more affordable than crystalline silicon cells in terms of cost, it is not preferred because its efficiency is still between 5-8%.^[28]

3.2.5. Solar Photovoltaic System Components

Apart from solar panels, different equipment is also used within solar energy systems and each of them plays a significant role in the system. Since solar panels produce direct current due to their structure, the alternating current used in industry or houses needs to be obtained through some conversion processes. While performing this conversion process, components are used in the system. It is stated that these components can be diversified for purposes such

as increasing the reliability of the system, monitoring system data and providing remote control. Introducing main components independently could help to imagine entire system and some working mechanism at whole. This section refers to the following main components of the photovoltaic system.

3.2.5.1. Solar Photovoltaic Modules

Solar panels, the most basic part of photovoltaic systems, are the part where electricity is produced from the sun. It converts solar energy into electrical energy through solar cells made of semiconductor silicon material that it contains in the solar panel. There are solar panels in different capacities. These vary according to the areas of solar cells and their arrangement. Figure 18 represents a single mono crystalline module.




Figure 18 : Mono Crystalline 400W Solar Module.^[34]

3.2.5.2. Array Mounting Racks

Solar panels can be installed in places such as buildings, industrial facilities and open fields. Specially designed structures are used for the placement of the panels. It is observed that these structures are produced from materials such as galvanized steel, aluminum, stainless steel, wood, and composite.

The angles of the mounting structures are determined according to the region where the solar panels will be placed, and the solar panels are placed on top of these structures. In this way, it is calculated that the panels will collect the maximum energy from the sun throughout the year.

Solar panel assembly structures can take many different forms. Figure 19 shows 9 different assembly structures that can be used for solar panels.




Figure 19 : Different Assembly Structures for Solar Panels.^[35]

These assembly structures,

For roof

1. With an additional structure on the roof cover,
2. As roof cover
3. Saw tooth on terrace roof
4. Terrace roof cover

For facade

5. With an additional structure on the facade surface
6. As facade cladding material

For different building sections

7. Parapet
8. Sunshades

For standalone systems

9. On soil background

3.2.5.3. Inverter

Inverters are electronic devices that convert DC electrical energy into AC electrical energy. For off-grid photovoltaic systems; square wave, sine and modified sine full three types are available. Modified sine and full sine models are frequently used in solar systems.

Inverters full sine models are two types, MPPT and PWM. New generation inverters used in solar systems are smart inverters that also include a charge controller. This type of inverters shows the user the production information of the solar panel, battery voltage values, electricity usage. These inverters contain a convector (AC-DC converter) so that batteries can be charged with mains or generator support.^[36]



Figure 20 : An Inverter for Off-grid PV system.^[36]

On-Grid, that is, inverters used in grid-connected photovoltaic systems are different. These inverters are specially produced for grid connections. It has features such as being able to work in coordination with the grid, providing electricity transfer from the network to the load as a result of the power drop in the panels. These are available in single and three phases. In these systems, the inverter power should be parallel to the panel power, unlike off-grid systems. On-Grid inverters have remote monitoring capability. The user can monitor the parameters such as the production of panels during the day, daily electricity consumption and total electricity production from a distance. The user can track its production and consumption wherever in the world. ^[36]



Figure 21: An Inverter for On-grid PV system.^[36]

3.2.5.4. Grounding Equipment

Grounding equipment provides a well-defined, low-resistance path from photovoltaic system to the ground to protect your system from current surges from lightning strikes or equipment malfunctions. Grounding also stabilizes voltages and provides a common reference point. The grounding harness is usually located on the roof when it is mounted top of the buildings, on the other hand if the system is placed in a field it is connected direct to the earth.^[37] Figure 22 which is shown below represents how it is grounded to earth soil.




Figure 22: Photovoltaic System Grounding Method.^[42]

3.2.5.5. Combiner Box

Wires from individual PV modules or strings are run to the combiner box, typically located on the roof. These wires may be single conductor pigtails with connectors that are pre-wired onto the PV modules. The output of the combiner box is one larger two wire conductor in conduit. A combiner box typically includes a safety fuse or breaker for each string and may include a surge protector.^[37] Figure 23 Represents a solar string combiner for PV application.



Figure 23 : Solar String Combiner for PV application.^[43]

3.2.5.6. Surge Protection

Surge protectors help to protect your system from power surges that may occur if the PV system or nearby power lines are struck by lightning. A power surge is an increase in voltage significantly above the design voltage.^[37]

3.2.5.7. Disconnects

Automatic and manual safety disconnects protect the wiring and components from power surges and other equipment malfunctions. They also ensure the system can be safely shut down and system components can be removed for maintenance and repair. For grid connected systems, safety disconnects ensure that the generating equipment is isolated from the grid, which is important for the safety of utility personnel. In general, a disconnect is needed for each source of power or energy storage device in the system.

For each of the functions listed below, it is not always necessary to provide a separate disconnect. For example, if an inverter is located outdoors, a single DC disconnect can serve the function of both the array DC disconnect and the inverter DC disconnect. Before omitting

a separate disconnect, however, consider if this will ever result in an unsafe condition when performing maintenance on any component. Also consider the convenience of the disconnects' location. An inconveniently located disconnect may lead to the tendency to leave the power on during maintenance, resulting in a safety hazard. [37]

3.2.5.8. Charge Controller

The charge controller regulates the dc energy from the solar panel and stabilizes it and creates a stable dc electrical energy for the charging of the batteries. In order to charge the batteries from a dc source, the charging current and voltage must be regulated constant. The voltage and current produced by the solar panel are not constant, so a charge controller is required for efficient charging of the batteries. Charge controllers also prevent reverse current from flowing from the battery to the panels. It protects the battery from overcharging. The charge controller cuts off electricity from the solar panel when the battery is full. It has two types. These; PWM (Pulse Width Modulation) and MPPT (Maximum Power Point Tracking) are charge control devices. [36]

3.2.5.9. Solar Energy System Cables

Solar panels are defined as generators that provide electricity from sunlight due to their structure. Because of these features, solar panels and other equipment connected to them are exposed to sun rays. It is stated that the cables, which connect the solar panels to each other and provide higher power, are affected by the sun's rays and high temperatures. Given that the working life of solar energy systems is more than 25 years, it is revealed that the cables connecting these systems must meet these conditions at least. However, due to the wear that may occur over the years, it is necessary to have special cables that connect the solar panels to minimize cable losses. In this context, with the development of the solar industry, cable manufacturers have started to manufacture special cables for these systems. The general characteristics of this type of cables are shown as their resistance against the harmful effects of sun rays and high temperatures and they carry DC electricity. Solar system cables are generally able to operate at temperatures between -40°C and $+120^{\circ}\text{C}$. These types of cables are commonly called "Solar Cable". [38] Figure 24 Shows specific cable type for Photovoltaic systems.



Figure 24 : An Example for Solar Cable [44]

3.2.5.10. Battery

Battery quality is very important for off grid photovoltaic systems with solar storage. The battery should have high charge-discharge efficiency and a long life. It must be resistant to temperature and adverse environmental conditions. We will discuss the technical details of these in another article. Batteries commonly used in solar systems; gel batteries, special opzs type aqueous batteries and some deep cycle lead acid batteries. ^[36]

3.2.6. Photovoltaic Systems by Usage

Photovoltaic solar systems are divided into two types according to their usage. These are grid independent and grid connected systems.

3.2.6.1. Grid Independent Systems (off-grid)

As the name implies, grid independent systems are PV systems that can meet the energy needs of a house or a consumption point separately from the grid. These systems are mostly preferred in areas remote to electricity generation facilities or distribution facilities, in regions where electricity is not yet available or costly to reach. In our country, such systems are predominantly preferred in vineyard houses, villages without electricity subscription, irrigation areas. The biggest advantage of these systems is that electricity produced from solar energy is consumed on-site without much loss. ^[39, 40]

Figure 25 shows the process flow chart of a grid-independent PV solar energy system. The electrical energy produced from the solar panels goes to the DC load via the charge controller via solar cables and the energy that is not consumed as DC is stored in the batteries. The charge controller acts as a control device here, directing the energy to the DC load when necessary, to the battery, and cutting the battery charge when the battery is fully charged. At the same time, it prevents energy loss by preventing the battery from discharging at night when electrical energy is not produced. In order to feed the AC loads in the system, conversion from DC to AC is performed with the inverter.^[40]




Figure 25 : Simple Off-grid system flow diagram.

3.2.6.2. Grid Connected Systems (on-grid)

Grid-connected PV systems are power generation facilities where there is an electricity line but where the energy generated is consumed, excess incoming energy is supplied to the grid, and the remaining energy is supplied from the grid. These systems can be installed and used on land or on the roofs of buildings. The components of this system are shown in Figure 21. Accordingly, electricity is produced through PV panels thanks to photons coming from the sun. The produced electricity passes through the inverter and converts from DC form to AC form. The converted electricity consumption is sent to the main panel of the consumption point and the need of the consumption point is provided by this generated energy. Another energy provider connected to the main panel is the grid. If the energy produced from the PV panels is insufficient, the remaining need of the energy and the consumption point is supplied continuously. If the energy produced from the PV panels is more than the need of the point of consumption, the excess energy generated is fed back into the grid. A bidirectional counter is provided on the grid side of the main panel of the consumption point in order to record the excess energy produced to the grid or to supply the energy that is missing for consumption from the grid. At the end of the month, the bidirectional meter takes the difference of the energy coming from the grid and the energy coming from the PV panel, revealing that the PV plant

owner is in the position of producer or consumer. This is called offsetting and offsetting is done at kWh, not at the price of electrical energy. [39,41]

Some facilities are very large, and a small part of the energy produced is used in domestic consumption. These facilities are mostly set up to generate profit from electricity generation and charge the electricity sold from electricity distribution companies every month. Most of the facilities in our country are works like this.




Figure 26 : Simple On-grid system flow diagram.

4. CHAPTER 4: CASE STUDY

4.1. Aim and General Information of the Project

This study is dedicated to design and implementing Photovoltaic electricity generation system in order to supply electricity for a university campus and selling overproduction to payback itself. The study mostly covers feasibility and best scenario of profitability. The used Materials and data are mostly realistic except deviations of simulation program which has been used.

The installed power of the solar power plant, which will be designed is planned as 9.5 MW. Adana province, known to have high solar energy potential, was chosen for the installation of the solar power plant.

The purpose of the solar power plant, which is planned to be installed, is to sell electricity directly to the grid also to meet the electricity needs of the university campus. The energy to be obtained from the solar power plant will be sent to the transformer which is inside the university and distributed to consumers from there. Within this scope, Weather condition data provided from Meteonorm software. To carry out the simulation with HELIOSCOPE software, consumption values per month and installed power agreement gathered from electricity bills which is obtained from university's general directorate of construction (Appendix 1). With these data simulation has generated. To design the lay out of the settlements of the solar modules area dimensions and suitable area information gathered from also university's general directorate of construction (Appendix 2). Design both generated in CAD and HELIOSCOPE the reason for making design at the two different programs is obtaining realistic design in CAD and cabling data and single line diagram in HELIOSCOPE. Electricity unit prices are obtained from EPDK and Electricity bills. With the data so far, economic analysis has been made. For payback time calculation, budget analysis will be carried out with the necessary information from the generated and obtained data. Budget offer information will be asked from the company that gives consultancy for setup process of renewable energy systems which name is ADAME. The data has been obtained thus far, such as the layout of the whole design, electrical schematic diagrams, the quantity of every component (solar modules, inverters and used cable length) These whole data will be sent to the ADAME company to ask an offer for projected system without any profit (Appendix 3).

When everything has considered,

- Is the Adana in the Mediterranean Region of Turkey suitable location for implement a solar power generation system?
- Is the area for settlement of the system enough for Installed power?

- Is this project feasible in terms of economically?
- Is this project applicable in real life?

4.2. Location

For this project Alparslan Turkes Science and Technology State University have been selected which is located in Adana, Turkey. The coordinates of the campus are (37.0394426099, 35.3848455917) (GMT 3.0). A satellite view of the location is given in the figure 27 below.




Figure 27: Alparslan Turkes Science and Technology State University,Adana(HELIOSCOPE)

4.3. Solar Radiation

Solar radiation data is defined as one of the most important parameters for solar power plants. During the feasibility studies, while calculating the amount of energy produced by a solar power plant, the radiation values obtained from the measurement stations are used. However, data obtained from a single measuring point may cause erroneous results due to errors that may occur at the measuring stations. Therefore, it is beneficial to use the data obtained from different measurement stations that are accepted while conducting solar feasibility studies. However, taking one-to-one measurements through a measuring station to

be installed in the region where the power plant will be installed is shown as factors that will increase the sensitivity of the feasibility studies.

Meteonorm is a commonly used weather source for international locations. This satellite weather source provides a uniform methodology for calculating irradiance and will always be within 10 km of the design site. In this study These data are provided by Meteonorm which is providing global irradiance database. Also, meteorological information of the powerplant area is almost near to meteorology station which is in US Military Airbase which is shown figure 28 below.

Description

Adana US military Base

Weather used to calculate the hourly performance of the array for a given year

Name	Distance
☒ 10km Grid, meteonorm (meteonorm) TMY ▼	4.6 km
☐ Gaziantep, Turkey, null (custom) TMY ▼	177.7 km
☐ Kayseri, Turkey, null (custom) TMY ▼	199.4 km
☐ Kayseri, Turkey, null (custom) TMY ▼	199.4 km
☐ Adiyaman, Turkey, null (custom) TMY ▼	268.2 km
☐ Adiyaman, Turkey, null (custom) TMY ▼	268.2 km
☐ Konya, Turkey, null (custom) TMY ▼	271.6 km
☐ Konva, Turkev, null (custom) TMY ▼	271.6 km

Harita
Uydu

Cancel

Create a New Condition Set

Figure 28 : Selecting Weather Condition Set for Determining Radiation (HELIOSCOPE)

After selecting the weather condition set Helioscope gives the monthly global irradiance values which is given in Table 2 and represented by chart in figure 29 shown below.

Table 2 : Monthly Global Irradiance Values

	January	February	March	April	May	June	July	August	September	October	November	December
kWh	66,9	77,9	118,6	147,2	187,8	205	205,3	211,8	148,3	110,7	70,9	59,1




Figure 29 : Monthly Global Irradiance Values

4.4. Installed Power and Monthly Consumption

From electricity bills and agreement of distribution company with the university, installed power is obtained as 9.504 kW. Transformers are already placed in university for further application.

Consumption values per month also obtained by electricity bills which is obtained from university's general directorate of construction. Table 3 and figure 30 which is shown below represents monthly consumption data of the campus:

Table 3: Consumption Data of The Campus

	January	February	March	April	May	June	July	August	September	October	November	December
kWh	281.024,10	238.755,30	220.386,60	172.323,90	164.404,8	185.314,5	232.262,1	210.999,6	223.719,3	166.603,5	178.346,7	250.028,1




Figure 30 : Monthly Consumption of the Campus.

On the other hand, from the electricity bills its assumed that the night-time usage as energy supplied from the grid monthly. It is also known as consumption made offset from production which is shown below as a table 4 and figure 31.

Table 4 : Consumption Made Offset from Production

January	February	March	April	May	June	July	August	September	October	November	December
37.262,7	71.911,1	74.865,4	63.134,8	57.860,5	57.598,4	65.033,4	59.079,9	62.641,4	58.445,1	63.829,1	19.654,3




Figure 31 : Consumption Made Offset from Production.

4.5. Energy Analysis and Production of The Solar Power Plant

Annual energy production of the solar power plant is stated as one of the most important parts of the further economic analysis of the solar power plant. For this study energy analysis carried out with Helioscope Simulation Software. As we mention previously, we are going to obtain necessary global irradiance data from Meteonorm Software.

Also, the data which is collected from GEPA (Solar Energy Potential Atlas) of the Turkey shows that suitable panel type is monocrystalline solar panels. Which is shown figure 32 below.




Figure 32 : Types of modules and its performance lines kWh/year per m2. (GEPA)

Solar Module and inverter type are selected in Helioscope which are shown table 5 below.

Table 5 : Selected Solar Module and Inverter.

Components		
Component	Name	Count
Inverters	SUN2000-100KTL-M1 (380/400) (Huawei)	77 (7.70 MW)
Module	AE Solar, AE400M6-72 (2020) (400W)	23,760 (9.50 MW)

Modules have 400 Wp Monocrystalline features. Inverters have adjustable Ac output features. The system is designed has 9504 kWp Dc power output and 7680 kWe Ac power output.

When Helioscope carried out the calculation and made the simulation, monthly production data is obtained as it shown in figure 33 below.



Figure 33 : Monthly Production Which is obtained from Helioscope.

As we can see from figure 33 which is shown above, annually production total is 9.489.042,5 kWh. Also, System metrics of the simulation is given in Figure 34.

 System Metrics	
Design	Design 1
Module DC Nameplate	9.50 MW
Inverter AC Nameplate	7.70 MW Load Ratio: 1.23
Annual Production	9.489 GWh
Performance Ratio	79.2%
kWh/kWp	998.4
Weather Dataset	TMY, 10km Grid, meteonorm (meteonorm)
Simulator Version	8df3ba8977-b5fd44241f-c7eec90fb7-0331dd75ba

Figure 34 : System metrics of the simulation from Helioscope.

4.6. Layout Design of Modules

Today's technology allows us to see everything from space by satellites. University's campus satellite images have been taken from google earth and using the layout of the rooftop plans and dimensions which is obtained from university's general directorate of construction. The collected whole data transferred to CAD program and roof mounted part of the study has done (Figure 35).



Figure 35 : Roof mounted Layout, Satellite Image from Google Earth with CAD Program.

Roof Mounted modules and inverters counted as 2646 modules and 8 inverters. This Number is not sufficient for total energy generation that desired. Inert area of university's campus also has been used for placement.

Ground mounted area has selected by university's general directorate of construction and after that same process carried out for that area either. Ground mounted modules and inverters are counted as 21114 modules and 69 inverters which can be observed in figure 36.




Figure 36 : Ground Mounted Layout, Satellite Image from Google Earth with CAD Program.

Number of panels that roof mounted and ground mounted are 23760 solar panels. Also, the number of inverters that used for this system is 77 in total. In figure 36 we can see the other inert area, which is shown empty with red border lines, university's general directorate of construction told that University will have more faculties and building in the future. If the design cannot meet the needs in the near future, we can make a project for that area either.

4.7. Economic Analysis of the Solar Power Plant

4.7.1. General

During the financial analysis of the 9.5 MW solar power plant, detailed financial analysis will be presented for the system, which is created by specifying the general definitions regarding the investment cost, project income and project expenses.

The establishment of the planned system of economic life of 25 years. Since the Connection Agreements to be made with the Distribution Company for the system planned to be made in connection with the grid are 10 years, the economic analysis was made to cover the 10 years with the Connection Agreement period. After the project approval of the university is received from the government institutions, the university will sign a connection agreement with the distribution company it is affiliated with. With the signing of the connection agreement, the distribution company guarantees that the established solar energy plant will receive the remainder of the electrical energy it will produce for 10 years after its internal consumption.

4.7.2. Currency Used in Financial Analysis

The general used currency is Turkish lira; however, some analyzes and total cost in this project were made on the basis of US Dollar (\$) and it was accepted that the US Dollar exchange rate was 6.85 TL / US Dollar(2020,July).

According to inflation and devaluation occurred in Turkey in the past years, except for the period of crisis, these two rates was almost equal, in other words, it is observed that prices remained almost constant in dollar terms that is why foreign currency is used. as the main reason for this situation, raw material production in Turkey and / or semi-manufactured and / or used equipment / installations noteworthy is shown a portion of that is imported. To put it briefly, after the devaluation, the manufacturer, who bought more expensive goods / equipment / tools in Turkish Lira, naturally reflects this increase in purchase prices to the consumer; this results in increased inflation. For this reason, it was accepted that the inflation and devaluation rates would increase almost equally during the project period, so there would be no significant change in the prices of non-imported materials and labor on the basis of Dollars, and therefore, in some of the financial analyzes, Dollars was used.

4.7.3. Projected Annual Fixed Expenses

Solar power plant is mostly constructed with electronical components and it may be affected by natural disasters because of that we need to make insurance for covering our unexpected incidents. There are several Insurance Companies who does Solar Power Plant Insurance in Turkey. The average given price per year is 13.700 Turkish Liras for 1MW. Furthermore, the plant needs to have workforce for security, maintain and cleaning the panel surfaces for better

performance. For this purpose, 5 workers needed, and minimum wage is 2.603 Turkish Liras per month. Table 6 shows total expense per year.

Table 6 : Total Annual Fixed Expenses.

	total expense per year
Insurance	130.150 TL
Workforce	156.180 TL

4.7.4. Unit Prices Used in the Project

During the Economic analysis of this study, Average unit price of the energy and distribution price are determined from university's electricity bills and EPDK's (Republic of Turkey Energy Market Regulatory Authority) energy prices is taken from its website. Table 7 shows the average unit prices of the energy and distribution price.

Table 7 : Unit Prices is Used for Study.

Unit Prices	
Energy Unit Price (Average)	0,417897 TL
Distribution Price (Average)	0,121495 TL
EPDK Energy Unit Price (Average)	0,520613 TL
US Dollar Currency	6,85 TL

The annual projected increase in unit prices used in the preparation of the economic analysis is given in Table 9. Table 8 is used for finding the ratio with using the old price.

Table 8 : Electricity Unit Price Between 2014-2020.

Year	Energy price (100kWh)	Percentage difference	Distribution Cost (100 kWh)	Percentage difference	Total (1 kWh)
2014	20,80 TL	-	7,75 TL	-	0,29 TL
2015	22,41 TL	7,71%	8,91 TL	14,86%	0,31 TL
2016	21,34 TL	-4,75%	10,32 TL	15,81%	0,32 TL
2017	21,41 TL	0,30%	10,25 TL	-0,63%	0,32 TL
2018	23,10 TL	7,90%	11,31 TL	10,33%	0,34 TL
2019	41,02 TL	77,59%	13,22 TL	16,92%	0,54 TL
2020	52,06 TL	26,91%	19,79 TL	49,64%	0,72 TL

According to EPDK (Republic of Turkey Energy Market Regulatory Authority) data, the rate of increase made is shown in the table previously. Also, graphical illustration of the increase in the electricity unit price is shown in Figure 37. Considering the increase rate compared to the previous year, annual average corresponds to an increase of around 17%.



Figure 37 : Electricity Unit Price Between 2014-2020.

When considering the annual increases of unit prices, it should not be forgotten that fixed expenses will increase at a certain rate annually. 10% was selected for the use of further calculations, as indicated in Table 8. For staying at the safe zone during the study these ratios of increases are also selected 10%.

Table 9 : Selected Annual Rate of Increase in Prices.

Annual Rate of Increase in Prices	
Electricity Unit Price Increase Rate	10,0%
Distribution Price Increase Rate	10,0%
Annual Fixed Expenses Increase Rate	10,0%

4.7.5. Consumption and Production Balance

Consumption data is gathered from University's electricity bills and mentioned at section 4 with table 3 which shows 12 months consumption values of the campus. Electricity bills are detailed specifically as day and night consumption either, with the help of that numbers we could calculate more accurately balances. Because, at the nighttime we must supply the needs from the grid directly due to not producing electricity from solar system.

On the other side, Production data is gathered from Helioscope simulation software and pointed at the section 5 with the figure 33 which shows monthly electricity production from simulated system.

Table 10 shows in detail about the consumption and production information of the solar power system during the period of 12 months and other necessary information such as offsetting values for further calculations.

Table 10 : The Consumption and Production Information of The Solar Power System During the Period of 12 Months.

Months	Consumption from Electricity Bills	Production from Simulation	Electricity Purchased from Grid after Offsetting	Electricity Sold to Grid after Offsetting	Electricity Consumed before Passing the Meter	Consumption Made Offset from Production
	kWh	kWh	kWh	kWh	kWh	kWh
January	-281.024,1	234.896,2	-46.127,9	0,0	197.633,5	37.262,7
February	-238.755,3	381.740,2	0,0	142.984,9	166.844,2	71.911,1
March	-220.386,6	671.234,2	0,0	450.847,6	145.521,2	74.865,4
April	-172.323,9	935.622,3	0,0	763.298,4	109.189,1	63.134,8
May	-164.404,8	1.291.582,5	0,0	1.127.177,7	106.544,3	57.860,5
June	-185.314,5	1.443.216,8	0,0	1.257.902,3	127.716,1	57.598,4
July	-232.262,1	1.403.156,8	0,0	1.170.894,7	167.228,7	65.033,4
August	-210.999,6	1.324.276,6	0,0	1.113.277,0	151.919,7	59.079,9
September	-223.719,3	834.915,9	0,0	611.196,6	161.077,9	62.641,4
October	-166.603,5	499.193,1	0,0	332.589,6	108.158,4	58.445,1
November	-178.346,7	280.445,2	0,0	102.098,5	114.517,6	63.829,1
December	-250.028,1	188.762,7	-61.265,4	0,0	169.108,4	19.654,3
Σ	-2.524.168,5	9.489.042,5	-107.393,3	7.072.267,3	1.725.459,1	691.316,1

From the table 10, Total annually consumption of the campus is calculated as 2.524.168,5 kWh and annually Production from the Solar Power Generation System is 9.489.042,5 kWh. When production and consumption information is compared, it is clear that the system to be installed is appropriate in terms of profitability. Because system is producing more than enough electricity that campus of the university consumes.

Furthermore, from the table 10 the electricity which is bought for meet the consumption value is just 107.393,3 kWh. The reason for this excess amount of the energy which is bought from the grid, in January and December global irradiance value is not enough for to produce electricity to meet the demand for these months. Moreover, the total amount of electricity which is consumed before passing the net-meter from produced electricity is 1.725.459,1 kWh annually.

Nevertheless, electricity which is sold to grid after offsetting is 7.072.267,3 kWh annually. It means that almost 75% of the produced electricity is sold to the grid.

It is known that sunshine duration of a region depends on the seasons and the earth's curvature. For instance, for Turkey's longest sunshine duration happens on June 21st, which is more than 12 hours, shortest sunshine duration happens on 21st of December. Except those days, on the September 23rd and March 21st day and night-time is equal to each other. So, when duration of the sunshine and working hours of the university considered, sometimes, we need to buy energy from grid to compensate the gap which is observed after sunshine usage. the Last column of the table 10 represents the value of the electricity which is supplied from the grid when the system is not producing electricity. The total number of the consumption made offset from production is 691.316,1 kWh annually.

4.7.6. Economical View After the System is Installed

This section mostly covers yearly income and expenses according to calculation after use of table 10. Electricity cost per kWh is accepted which is shown in table 10 which obtained from EPDK (Republic of Turkey Energy Market Regulatory Authority) and selling price for offsetting obtained from electricity distributors. When we gather and use together the table 10 and table 11, Economy of the system will be obtained.

Table 11 : Unit Price of Electricity for Calculation.

	2019	2020	Selling Price For offsetting
January	₺0,55	₺0,61	₺0,49
February	₺0,56	₺0,61	₺0,49
March	₺0,56	₺0,61	₺0,49
April	₺0,56	₺0,62	₺0,50
May	₺0,57	₺0,63	₺0,51
June	₺0,56	₺0,62	₺0,50
July	₺0,64	₺0,71	₺0,57
August	₺0,64	₺0,71	₺0,58
September	₺0,64	₺0,71	₺0,58
October	₺0,57	₺0,63	₺0,50
November	₺0,57	₺0,63	₺0,51
December	₺0,58	₺0,63	₺0,51

Electricity per kWh purchase price from the grid is represented in first column and second column of the table 11. Moreover, for offset selling price per kWh to the grid is represented in third column. Fixed expenses annually obtained from table 6 and separated per month. After making the necessary calculations using the data from table 10 and 11, the economic situation arises monthly in table 12.

Table 12 : Cash Flow After the System Installed

Months	Cash Flow After the System Installed							
	Consumption Price According to 2019 Electricity Price	Consumption Price According to 2020 Electricity Price	New Expense According to Electricity Consumption		Income from Electricity Produced	Savings Provided by the Energy Consumption Without Passing the Net-Meter	Fixed Expenses	Net Cash Flow
			Bought	Made Offset				
	₺	₺	₺	₺	₺	₺	₺	₺
	A	B	C	D	E	F	G	H
January	-155.655,50 ₺	-171.221,05 ₺	-27.369 ₺	-2.489,97 ₺	0,00 ₺	119.053,44 ₺	-23.860,83 ₺	115.405,87 ₺
February	-132.946,69 ₺	-146.241,36 ₺	0 ₺	-4.805,25 ₺	74.439,80 ₺	102.194,66 ₺	-23.860,83 ₺	192.015,08 ₺
March	-122.866,37 ₺	-135.153,01 ₺	0 ₺	-5.002,66 ₺	234.717,12 ₺	89.241,48 ₺	-23.860,83 ₺	341.006,64 ₺
April	-97.285,87 ₺	-107.014,46 ₺	0 ₺	-4.218,80 ₺	397.383,07 ₺	67.807,25 ₺	-23.860,83 ₺	476.317,90 ₺
May	-94.075,14 ₺	-103.482,66 ₺	0 ₺	-3.866,35 ₺	586.823,36 ₺	67.063,08 ₺	-23.860,83 ₺	662.578,84 ₺
June	-104.310,40 ₺	-114.741,44 ₺	0 ₺	-3.848,84 ₺	654.880,29 ₺	79.078,17 ₺	-23.860,83 ₺	741.912,05 ₺
July	-148.975,46 ₺	-163.873,00 ₺	0 ₺	-4.345,66 ₺	609.583,00 ₺	117.988,56 ₺	-23.860,83 ₺	745.249,51 ₺
August	-135.740,72 ₺	-149.314,79 ₺	0 ₺	-3.947,84 ₺	579.586,48 ₺	107.506,65 ₺	-23.860,83 ₺	701.092,60 ₺
September	-143.658,05 ₺	-158.023,86 ₺	0 ₺	-4.185,83 ₺	318.196,90 ₺	113.777,18 ₺	-23.860,83 ₺	448.174,09 ₺
October	-95.075,16 ₺	-104.582,68 ₺	0 ₺	-3.905,42 ₺	173.150,47 ₺	67.894,70 ₺	-23.860,83 ₺	249.966,89 ₺
November	-102.225,36 ₺	-112.447,90 ₺	0 ₺	-4.265,19 ₺	53.153,81 ₺	72.203,56 ₺	-23.860,83 ₺	137.475,69 ₺
December	-143.838,39 ₺	-158.222,23 ₺	-36.351 ₺	-1.313,34 ₺	0,00 ₺	107.132,81 ₺	-23.860,83 ₺	94.396,24 ₺
Σ	-1.476.653,13 ₺	-1.624.318,44 ₺	-63.720 ₺	-46.195,14 ₺	3.681.914,30 ₺	1.110.941,54 ₺	-286.330,00 ₺	4.905.591,41 ₺

University's 2019 electricity expense is shown in table 12 as column 'A' and as can be seen from the table total expense for electricity is 1.476.653,13 TL, from column 'B' 1.624.318.44 TL in 2020. For calculating this expenses unit price of the electricity is taken from table 2.

University's new electricity expense will be derived from the sum of the two columns which are 'C' and 'D'. The price that university should pay for the electricity distribution company is totally 109.915,14 TL.

Column 'D' is the difference between two price which is from electricity purchase price to electricity sell price while calculating the offset electricity.

Column 'E' represents the income from the sold electricity to distribution company.

Column 'F' represents the savings due to electricity consumption without passing the net-meter.

Column 'G' represents the fixed expenses which is explained in section 3.

Column 'H' finally shows the Net cash flow sum of column 'E','F' and saving from offset electricity which is 399.065,57 TL.

When everything is considered from the table 12. Annually net cash flow after the system is installed is 4.905.591.41 TL.

Table 13 shows the Consumption Cost before the system Installed which contains electricity bills before electricity generation, Consumption Cost after the system Installed that represents electricity bills after the usage of electricity generation this value can be zero sometimes do to overproduction of the generation system and lastly the Total Saving after the system Installed values which is net cash flow or total savings of the system .For better illustration total of these values Figure 38 illustrates with graph.

Table 13 : Costs and saving from consumption and production.

	January	February	March	April	May	June	July	August	September	October	November	December
Consumption Cost before the system Installed	- 155.655,5 0 ๕	- 132.946,6 9 ๕	- 122.866,3 7 ๕	- 97.285,8 7 ๕	- 94.075,1 4 ๕	- 104.310,4 0 ๕	- 148.975, 46 ๕	- 135.740, 72 ๕	-143.658,05 ๕	- 95.075,1 6 ๕	-102.225,36 ๕	- 143.838,39 ๕
Consumption Cost after the system Installed	- ๕29.859,0 8	-๕4.805,25	-๕5.002,66	-๕4.218,8 0	-๕3.866,3 5	-๕3.848,84	-๕4.345,6 6	-๕3.947,8 4	-๕4.185,83	-๕3.905,4 2	-๕4.265,19	- ๕37.664,00
Total Saving after the system Installed	115.405,8 7 ๕	192.015,0 8 ๕	341.006,6 4 ๕	476.317, 90 ๕	662.578, 84 ๕	741.912,0 5 ๕	745.249, 51 ๕	701.092, 60 ๕	448.174,09 ๕	249.966, 89 ๕	137.475,69 ๕	94.396,24 ๕




Figure 38 : Balance Graph for Income and Expense.

4.7.7. Economical View for 10 Years

After having some concrete values from previous section and as far as it is known that 10 years is a threshold value of such a study which is in meaning of profitability and reasonability in investment projects. In this part of this study, it is assumed as the loss ratio for every year is 0,7% for production. Loss ratio is used because, from the moment solar panels are used, they start to lose their production performance. It is accepted at the previous sections of this study electricity prices and fixed expenses are increasing 10% every year. Economical view of this study consists of basically production of the electricity, consumption of the electricity and Income from the electricity which is sold to grid. When necessary ratios applied to the results of the calculations in previous chapters, Economical view will arise. From the table 14 and figure 39 which is shown below, economical view for a decade can be observed.

Table 14 : Economical View for A Decade

YEARS	Annually Consumption According to Electricity Bills	Production According to Simulation	Expenses According to 2019 Electricity price	Expenses According to 2020 Electricity price	New Expenses According to Production	Income from Sold Electricity to Grid	Net Cash Flow
	kWh	kWh	₺	₺	₺	₺	₺
1.	-2.524.168,5	9.489.042,5	-1.476.653,1 ₺	-1.624.318,4 ₺	-109.914,9 ₺	3.681.914,30 ₺	4.905.591,41 ₺
2.	-2.524.168,5	9.422.619,2	-1.624.318,4 ₺	-1.786.750,3 ₺	-122.624,0 ₺	4.013.765,14 ₺	5.357.955,65 ₺
3.	-2.524.168,5	9.356.660,9	-1.786.750,3 ₺	-1.965.425,3 ₺	-136.762,4 ₺	4.375.446,83 ₺	5.852.030,92 ₺
4.	-2.524.168,5	9.291.164,2	-1.965.425,3 ₺	-2.161.967,8 ₺	-152.488,0 ₺	4.769.632,86 ₺	6.391.662,95 ₺
5.	-2.524.168,5	9.226.126,1	-2.161.967,8 ₺	-2.378.164,6 ₺	-169.975,1 ₺	5.199.235,49 ₺	6.981.051,96 ₺
6.	-2.524.168,5	9.161.543,2	-2.378.164,6 ₺	-2.615.981,1 ₺	-189.417,7 ₺	5.667.426,99 ₺	7.624.785,43 ₺
7.	-2.524.168,5	9.097.412,4	-2.615.981,1 ₺	-2.877.579,2 ₺	-211.030,1 ₺	6.177.662,78 ₺	8.327.873,74 ₺
8.	-2.524.168,5	9.033.730,5	-2.877.579,2 ₺	-3.165.337,1 ₺	-235.050,3 ₺	6.733.706,56 ₺	9.095.789,17 ₺
9.	-2.524.168,5	8.970.494,4	-3.165.337,1 ₺	-3.481.870,8 ₺	-261.741,8 ₺	7.339.657,72 ₺	9.934.508,45 ₺
10.	-2.524.168,5	8.907.700,9	-3.481.870,8 ₺	-3.830.057,9 ₺	-291.396,5 ₺	7.999.981,19 ₺	10.850.559,32 ₺
Σ	-25.241.685	91.956.494	-23.534.047,9 ₺	-25.887.452,7 ₺	-1.880.400,9 ₺	55.958.429,86 ₺	75.321.809,0 ₺




Figure 39: Economical View for A Decade

The figure above shows the amount of earnings with the system's savings for each year. The amount of earnings increases due to increases in the electricity bill each year. Cumulatively, total savings at the end of the 10th year are estimated at 75,321,808.99 TL.

4.7.8. Setup Process and Budget Analysis

In this section of this study, it is mentioned about the possible setup process which is consist of basics steps for setting up a solar power generation system in Turkey.

First, University needs to apply for invitation letter for 7680 kW AC installed power to the electricity distribution company which is signed the contract with before. Then, invitation letter will be provided the electricity distribution company to the university.

Secondly, After the invitation letter provided to the university, the university needs to send the related project about solar power generation to the Turkey's Electricity Distribution Co. (TEDAS) to be accepted. Necessary discoveries and studies will be carried out before project approval, and project approval will be obtained as a result of these studies.

Third, After the getting approval of the project from Turkey's Electricity Distribution Co. (TEDAS), connection agreement needs to be signed with the electricity distribution company which is signed the contract with before.

Last, with the approval from Turkey's Electricity Distribution Co. (TEDAS) and connection agreement with distribution company, University can start to setup and produce electricity.

Budget analysis will be carried out with the necessary information from the previous chapters and information from the company gives consultancy for setup process of renewable energy systems which name is ADAME. From the simulation software the layout of the whole

design, electrical schematic diagrams, the quantity of every component (solar modules, inverters and used cable length) obtained. These data are sent to the ADAME company to offer a price for projected system without any profit. The reason of using such a company for price offer is when a company used for such a project can use the benefits of governmental incentives. One of these incentives is deduction of Value-added tax. Another reason, these companies being qualified for the money to be spent on the details of the installation. Such as workforce, cables, necessary equipment and instruments. The budget list is provided from ADAME company has given in appendix 3.

The price for needs to installment for this study is provided from ADAME company is 544,2 \$ per kW. The study has 9504 kW and total budget arises as 5.172.076,80 \$.

4.7.9. Payback time

From the previous section of this study the project budget is showed up as 5.172.076,80\$. It is equal to 35.428.726.1 TL. From the table 14 the first 6 years income is equal to 37.113.078,32 TL. Project will payback itself after installation approximately in 6 years. The threshold for this study is selected 10 years and when the government's 10 year buying guarantee is considered, the project is completely suitable to make it in real life.

CONCLUSION

Limited reserves and fluctuations in fossil fuel resources prices, energy-related greenhouse gas emissions have been led to a transformation in favor of renewable energy resources. Developing countries are building solar power plants not only because of it is safe, environment friendly and sustainable. But also, they are building such power plants to protect themselves from a possible energy crisis and its negative impacts at their economy. The plants that they are planning to build helps to strengthen their economies and create new employment areas. For this purpose, with the incentive policies are developed in many countries. Either the power generation industry from solar energy has qualified more and the installed power of the solar power plants has increased rapidly. Research and development processes that have been made intensively since past to present about PV technologies has led to increase in production efficiency as well as lifespan of the solar power generation systems. Furthermore, the unit price of these systems is decreasing day by day which is also make these systems more attractive for investors in energy industry. As far as it is known with the use of developed and newest technologies some areas which has high irradiance value are producing almost the same energy as much as conventional systems when it is compared to unit price of the electricity.

On the other hand, Turkey is a country that energy needs increase every year and meet the large portion of these needs with imported resources. Therefore, this situation makes the Turkey with a high dependence on imported energy. For this purpose, solar power plants are serious option for Turkey due to decreasing unit cost of the building a plant. What makes it also attractive for investors is that the government will buy every kWh of energy produced for 15 years with incentives at a guaranteed price. Moreover, Sarıcam is developing part of Adana province, it will be easier to reduce transmission and transportation losses due to meeting the increasing energy need of the Sarıcam region with an energy producing facility directly within the province's borders.

As a result of the studies conducted within the scope of this thesis, it is concluded that Adana province is efficient enough for possible investment in building a solar power plant. Moreover, University has enough suitable location for mounting the solar panels which is observed when layout design is carried out with CAD software. Furthermore, GEPA indicates that monocrystalline solar modules are the most suitable for selected region. Energy analysis which is done with HELIOSCOPE simulation software shows that system works effectively and generates enough energy with global irradiance values which is obtained from METEONORM software. What is more, when we used gathered electricity bills data, layout data and simulation data all together economical result has arisen. This economic data can be frightening at the first sight but when we carry out with budget cost to calculate payback time

implementing such a power plant is possible. Profitability and carried out analysis make the project applicable to real life.





REFERENCES

1. <https://en.wikipedia.org/wiki/Turkey>
2. https://en.wikipedia.org/wiki/Mediterranean_Region,_Turkey
3. <http://www.allaboutturkey.com/mediterranean.htm>
4. <https://en.wikipedia.org/wiki/Adana>
5. <http://www.enerji.gov.tr/tr-TR/Sayfalar/Gunes> , last Access 10.01.2020.
6. <http://www.yegm.gov.tr/MyCalculator/Default.aspx> , last Access 10.01.2020
7. <http://gunesenerjisi.uzerine.com/index.jsp?objid=705> , Last Access 10.01.2020
8. Atakan, Y. (2020). "Rüzgâr ve Güneş Enerjilerinden Elektrik Üretiminde Gelişmeler Almanya ile Türkiye karşılaştırması", FMO. <https://www.fmo.org.tr/wp-content/uploads/2020/01/GUNES-ENERJISINDEN-ELEKTRIK-atakan-FMOX-17-Ocak-2020.pdf> , Last access 18.01.2020
9. Yılmaz, Ş. (2020). "DÜNYADA VE TÜRKİYE'DE BİRİNCİL ENERJİ ARZI", TMMOB, TÜRKİYE'NİN ENERJİ GÖRÜNÜMÜ 2020, Ankara, **Yayın No:** 717, pp 5-12.
10. Özgür, E. (2020). "TÜRKİYE'DE GÜNEŞ ENERJİSİ", TMMOB, TÜRKİYE'NİN ENERJİ GÖRÜNÜMÜ 2020, Ankara, **Yayın No:** 717, pp 297-316.
11. <http://www.eigm.gov.tr/tr-TR/Denge-Tablolari/Denge-Tablolari>, Last Access 12.01.2020.
12. Varınca, K. B., & Gönüllü, M. T. (2006). Türkiye'de güneş enerjisi potansiyeli ve bu potansiyelin kullanım derecesi, yöntemi ve yaygınlığı üzerine bir araştırma. *Ulusal güneş ve hidrojen enerjisi kongresi*, 21-23.
13. Kılıç, A., & Öztürk, A. (1983). *Güneş enerjisi*. Kipaş Dağıtımçılık.
14. https://birimler.dpu.edu.tr/app/views/panel/ckfinder/userfiles/48/files/alt_ener_kay_der_s_notlari.pdf
15. https://commons.wikimedia.org/wiki/File:Global_Energy_Potential_2014_08_09.svg
16. https://news.softpedia.com/news/EPA-Classifies-Global-Warming-as-Public-Danger-107594.shtml#sqal_0
17. <https://www.universetoday.com/16338/the-sun/>
18. Cameron, P., & Crompton, G. (2008). Solar Power Plant Pre-feasibility Study. *Report No. 2158583A-RPT001-Qbhpcf, Parsons Brinckerhoff Australia Pty Limited*
19. Mallon, K. R., Assadian, F., & Fu, B. (2017). Analysis of on-board photovoltaics for a battery electric bus and their impact on battery lifespan. *Energies*, 10(7), 943.
20. Patel, M., R., 1999, Wind and solar power systems, New York, USA http://library.uniteddiversity.coop/Energy/Wind/Wind_and_Solar_Power_Systems.pdf
21. <http://www.britannica.com/EBchecked/topic/58017/Antoine-CesarBecquerel>
22. <http://www.nrel.gov/docs/fy04osti/33947.pdf>

23. Karamanav, M. (2007). Güneş enerjisi ve güneş pilleri. *Sakarya Üniversitesi, Yüksek Lisans Tezi*, Sayfa, 1-8.
24. Singh, J. (2001), "Semiconductors Band Structures", *Semiconductor Devices: Basic Principles*, John Wiley & Sons, Inc., New York, 2-3
25. Pászti, Z., Petö, G., Horváth, Z. E., Karacs, A., & Guczi, L. (1997). Formation and valence band density of states of nonspherical Cu nanoparticles deposited on Si (100) substrate. *The Journal of Physical Chemistry B*, 101(12), 2109-2115.
26. <https://jeemargdarshak.wordpress.com/2014/03/17/classification-of-metals-conductors-and-semiconductors/>
27. <https://www.science.org.au/curious/technology-future/solar-pv>
28. Bagher, A. M., Vahid, M. M. A., & Mohsen, M. (2015). Types of solar cells and application. *American Journal of optics and Photonics*, 3(5), 94-113.
29. Glunz, S. W., Preu, R., & Biro, D. (2012). Crystalline silicon solar cells: state-of-the-art and future developments. *Comprehensive renewable energy*, 1, 353-387.
30. ARSLAN, İ. (2018). *Tekirdağ koşullarında polikristal ve monokristal tip pv güneş panellerinin verimlilik karşılaştırılması* (Master's thesis, Namık Kemal Üniversitesi).
31. Kumar, A., Richhariya, G., & Sharma, A. (2015). Solar photovoltaic technology and its sustainability. In *Energy sustainability through green energy* (pp. 3-25). Springer, New Delhi.
32. Lynn, P. A. (2011). *Electricity from sunlight: an introduction to photovoltaics*. John Wiley & Sons.
33. https://tr.m.wikipedia.org/wiki/Dosya:Comparison_solar_cell_poly-Si_vs_mono-Si.png
34. <https://www.ankarasolar.com.tr/urun-detay/as-m72-370-400w-mono-perc-solar-panel/>
35. Deutsche Gesellschaft für Sonnenenergie (Dgs), D. (2008). Planning and Installing Photovoltaic Systems. London: Routledge, <https://doi.org/10.4324/9781849772174>
36. Leblebicioglu, E., 2017. "Fotovoltaik (PV) Solar Sistem ve Bileşenleri" September <https://muhendistan.com/fotovoltaik-sistemler-nedir/>
37. Roos, C. J. (2009). Solar electric system design, operation and installation: an overview for builders in the US Pacific Northwest.
38. <https://tr.prysmiangroup.com/sites/default/files/atoms/files/Solar-Brosur-01.pdf>
39. Ceylan, İ., & Gürel, A.E. (2018). "Güneş Enerjisi Sistemleri ve Tasarımları", Dora Basım-Yayı Dağıtım, Bursa, 95-98.
40. Uysal, N. (2011). *Konya ili için güneş ve rüzgar enerjisinden elektrik üretimi ve kullanımının araştırılması* (Doctoral dissertation, Selçuk Üniversitesi Fen Bilimleri Enstitüsü).
41. Markwart, T., (2000). "Solar Electricity, 2nd Edition", Wiley, U.K.

42. Wiles, J. C. (2012). Photovoltaic system grounding. *Solar America Board for Codes and Standards Report*.
43. <https://new.abb.com/products/1SLM302000A5740/stringbox-dc-20str-monitor-1000v-1f-15a>
44. https://www.helukabel.com/us/products/solarflex-x-h1z2z2-k-1x4-mm-bk-opc-SOL_713530.html





Acronyms and Abbreviations

AC: Alternating Current

a-Si: Amorphous Silicon

B: Boron

°C: Celsius

CAD: Computer Aided Design

cdTe: Cadmium Telluride

CIGS: Copper Indium Gallium Selenide

CSP: Concentrated Solar Power

DC: Direct Current

°: degree

EPDK: Republic of Turkey Energy Market Regulatory Authority

GEPA: Solar Energy Potential Atlas

GMT: Greenwich Mean Time

HELIOSCOPE: Design and Simulation Software

J: Joule

°K: Kelvin

kg: Kilogram

km: Kilometer

kW: Kilowatt

kWh: Kilowatt-hour

MW: Megawatt

m: Meter

Meteonorm: Weather Database Program

Mono-Si: Monocrystalline Silicon

MPPT: Maximum Power Point Tracking

OPZS: Ortsfest PanZerplatte Flüssig (Stationary Tubular Plate Flooded)

P:Phosphorus

PV:Photovoltaic

Poly-Si:Polycrystalline Silicon

PWM:Pulse Width Modulation

RES:Renewable Energy Source

R&D: Research and Development

Si:Silicon

S:SolarInvariable

₺:Turkish lira

TL: Turkish Lira

TOE:Tonne of Oil Equivalent

TW:Terrawatt

US: United States

Σ :Sum symbol



List of Figures

Figure 1 : Mediterranean Region of Turkey. ^[3]	3
Figure 2: Turkey's Solar Energy Potential Atlas. ^[6]	6
Figure 3: Turkey Distribution of Energy Supply by 2018 Primary Sources. ^[9]	8
Figure 4: Turkey's Primary Energy Supply Change During the Years. ^[9]	8
Figure 5: Use of Solar Energy in Primary Energy Source Change Graph by Years. ^[10]	9
Figure 6: Sun. ^[17]	10
Figure 7: Global Energy Potential. Comparison of renewable and conventional energy sources. For renewable, the amount of energy is shown per year, while for conventional sources the total reserve is displayed. ^[15]	12
Figure 8 : Distribution of the sun's rays falling on the earth. ^[16]	12
Figure 9 : Types of Solar Radiations. ^[19]	13
Figure 10: Energy Levels of Conductor, Semiconductor and Insulator. ^[26]	16
Figure 11: Silicon Atom and its Chemical Structure. ^[27]	17
Figure 12: Obtaining n-type material after doping process. ^[27]	18
Figure 13: Obtaining p-type material after doping process. ^[27]	18
Figure 14: Combination of P type and N type material. ^[27]	19
Figure 15 : Presentation of a Solar Cell	20
Figure 16 : Monocrystalline silicon cell example. ^[35]	21
Figure 17: Representations of Polycrystalline Silicon Cells (left side) and Monocrystalline Silicon Cells (right). ^[33]	22
Figure 18 : Mono Crystalline 400W Solar Module. ^[34]	23
Figure 19 : Different Assembly Structures for Solar Panels. ^[35]	24
Figure 20 : An Inverter for Off-grid PV system. ^[36]	25
Figure 21: An Inverter for On-grid PV system. ^[36]	26
Figure 22: Photovoltaic System Grounding Method. ^[42]	26
Figure 23 : Solar String Combiner for PV application. ^[43]	27
Figure 24 : An Example for Solar Cable ^[44]	28
Figure 25 : Simple Off-grid system flow diagram.	30
Figure 26 : Simple On-grid system flow diagram.	31
Figure 27: Alparslan Turkes Science and Technology State University,Adana(HELIOSCOPE)	33
Figure 28 : Selecting Weather Condition Set for Determining Radiation (HELIOSCOPE)	34
Figure 29 : Monthly Global Irradiance Values	35
Figure 30 : Monthly Consumption of the Campus	36
Figure 31 : Consumption Made Offset from Production.	37
Figure 32 : Types of modules and its performance lines kWh/year per m2. (GEPA)	38
Figure 33 : Monthly Production Which is obtained from Helioscope	39
Figure 34 : System metrics of the simulation from Helioscope.	40
Figure 35 : Roof mounted Layout, Satellite Image from Google Earth with CAD Program.	41
Figure 36 : Ground Mounted Layout, Satellite Image from Google Earth with CAD Program.	42
Figure 37 : Electricity Unit Price Between 2014-2020.	45
Figure 38 : Balance Graph for Income and Expense.	52
Figure 39: Economical View for A Decade	54



List of Tables

Table 1: Solar energy and Radiation time for every region. ^[7]	7
Table 2 : Monthly Global Irradiance Values	35
Table 3: Consumption Data of The Campus.....	36
Table 4 : Consumption Made Offset from Production.....	37
Table 5 : Selected Solar Module and Inverter.	38
Table 6 : Total Annual Fixed Expenses.	44
Table 7 : Unit Prices is Used for Study.	44
Table 8 : Electricity Unit Price Between 2014-2020.....	45
Table 9 : Selected Annual Rate of Increase in Prices.	46
Table 10 : The Consumption and Production Information of The Solar Power System During the Period of 12 Months.	47
Table 11 : Unit Price of Electricity for Calculation.	49
Table 12 : Cash Flow After the System Installed.....	50
Table 13 : Costs and saving from consumption and production.....	52
Table 14 : Economical View for A Decade	53



List of Appendices

Appendix 1 : Electricity Bills and Installed Power Agreement.....	71
Appendix 2 : Suitable Areas and Layout Information with a Map	94
Appendix 3 : Price Offer from ADAME for Budget Analysis.....	96
Appendix 4 : Simulation Summary	97



[illegible]

MÜŞTERİ BİLGİLERİ

UZLEŞME HESAP NO : 1014969806
TESİSAT NO : 4010887923
MÜŞTERİ NO : 208934564
MÜŞTERİ ADI SOYADI : ADANA BİLİM VE TEKNOLOJİ ÜNİVERSİTESİ İDARİ VE MALİ
VERGİ DAİRESİ - VKN : 208934564
MÜŞTERİ GRUBU : ZİYAPASA VD - 0070600644
TESİSAT ADRESİ : Tek Terimli Tek Zamanlı Ticaret Hane OG (Orta Gerilim)
Son Kaynak Tarifesi Serbest Tüketim
GÜLTEPE MAH. ÇATALAN CD. NO 20 YÜBÜTÜ KAMPÜSÜ
MERKEZ SARIÇAM ADANA
OTOMATİK ÖDEME TALİMATI : YOKTUR
FATURA TARİHİ / DÖNEMİ : 15.12.2017 - 12.11.2017

e-Arşiv Fatura

Fatura Seri, Sıra No: 3M12017000183526

ORTALAMA TÜKETİM (kWh/gün)

ENERJİSA TOROSLAR ELEKTRİK PERAKENDE SATIŞ A.Ş.
BAĞLARBAŞI MAH. REFAHEVLER SOK.
A BLOK NO:2/1 MALTEPE/İSTANBUL
KÜÇÜKYALI V.D. 8560366451
Mersis No : 856036645100015
Tic. Sic. No : 521047
Tel / Faks : (0216) 579 05 00 / (0216) 579 05 30
Web Sitesi : www.toroslarepsas.enerjisa.com.tr
online.enerjisa.com.tr

4007 Tarih: 9.12.2017 Sayı: 268

0 Ocak Şubat Mart Nisan Mayıs Haziran Temmuz Ağustos Eylül Ekim Kasım Aralık

TÜKETİM BİLGİLERİ

	Tek Zaman	Gündüz	Puant	Gece
İlk Endeks		47,383	15,448	20,552
Son Endeks		57,314	17,605	23,890
Endeks Farkı		9,931	2,157	3,338
Çarpan		6.300,000	6.300,000	6.300,000
Traf. Tüketim (kWh)	97.183,800	62.565,300	13.589,100	21.029,400
Ek Tüketim (kWh)				
Trafo Boşta Kaybı (kWh)				
Ek Trafo Boşta Kaybı (kWh)				

REAKTİF TÜKETİM BİLGİLERİ

	Endüktif	Kapasitif	GÜÇ VE GÜÇ AŞIMI
İlk Endeks	3,189	14,852	Sayaç Demand Değeri
Son Endeks	4,713	15,021	Çarpan
Endeks Farkı	1,524	0,169	Demand (Güç)
Çarpan	6.300,000	6.300,000	Anlaşım Gücü (kW)
Reaktif Tüketim (kVARh)	9.601,280	1.064,700	Güç Aşımı
Fatura Edilen Reaktif (kVARh)			Ek Güç
Ek Reaktif Tüketim (kVARh)			Ek Güç Aşımı
REAKTİF TÜKETİM ORANI			

AKTİF TÜKETİM BİRİM FİYATLARI

	Tek Zaman	Gündüz	Puant	Gece
Tek Zaman Aktif Tüketim	0,21615700			
İndirilmiş Aktif Tüketim				
Ek Aktif Tüketim				
Gündüz Aktif Tüketim				
İndirilmiş Aktif Tüketim				
Ek Aktif Tüketim				
Puant Aktif Tüketim				
İndirilmiş Aktif Tüketim				
Ek Aktif Tüketim				
Gece Aktif Tüketim				
İndirilmiş Aktif Tüketim				
Ek Aktif Tüketim				
İNDİRİM ORANI				

OKUMA BİLGİLERİ

Aktif Sayaç Seri No/Marka	80087278/MAKEL	İlk Okuma Tarihi	06.12.2017
Endüktif Sayaç Seri No/Marka	80087278/MAKEL	Son Okuma Tarihi	20.12.2017
Kapasitif Sayaç Seri No/Marka	80087278/MAKEL	Sonraki Okuma Dönemi	12.2017
Akım Trafo Oranı - Gerilim Trafo Oranı	100,0/ 5,00 - 31.500/ 100,0	Ort.Tük. (kWh/gün)	6.478,920
Saymanlık Adı		Önceki Yıl Tük.(kWh)	
Tekil Kod	4010887923	Carl Yıl Tük. (kWh)	622.496,700
		Sayaç Okuma Birim	71120020

MESAJINIZ VAR

BEDELLER

ENERJİ TÜKETİMİ (t)	21.007,93
Tek Zaman Tüketim Bedeli	21.007,93
Gündüz Tüketim Bedeli	
Puant Tüketim Bedeli	
Gece Tüketim Bedeli	
Ek Aktif Tüketim Bedeli	
Trafo Boşta Kaybı Bedeli	
Ek Trafo Boşta Kaybı Bedeli	
(W-) Tutar	
SİSTEM KULLANIM (t)	9.758,91
Dağıtım Bedeli	9.758,91
Güç Bedeli	
Ek Güç Bedeli	
Güç Aşımı Bedeli	
Ek Güç Aşımı Bedeli	
Reaktif Bedeli	
Ek Reaktif Bedeli	
Borçtan K/B Bedeli	

DİĞER (t)

Gecikme Zammı Bedeli (%1,40)	155,08
Dağıtım Bağlantı Bedeli	
Per. Abn. K/B Bedeli	

VERGİ/FONLAR (t)

Enerji Fonu	210,08
TRT Payı	420,16
Elektrik ve Havagazı Tüketim Vergisi	1.050,40
KDV	5.868,46

FATURA TUTARI (t)

Muhtelif Mahsup	
Önceki Dönem Yuvarlama Farkı	
Yuvarlama Farkı	
Damga Vergisi	-309,07

ÖDENECEK TUTAR (t)

38.161,95

Ödemenizi yapmanız için lütfen aşağıdaki bilgileri dikkate alınız.

VERGİLER TOPLAMI: 7.549,10

KDV MATRAHI: 32.602,96

SON ÖDEME TARİHİ: 17.01.2018

ESKİ BORÇ/BAKİYE (t): 0,00

Ödemelerinizi zamanında yaptığınız için teşekkür ederiz.

BİLGİLERİ

ESKİME HESAP NO: 1014968006

SİCİL NO: 4010887923

MÜŞTERİ NO: 208034564

VERGİ DAİRESİ: VKN / TCKN: ADANA BİLİM VE TEKNOLOJİ ÜNİVERSİTESİ İDARI VE MALİ ZİYAPASA YOLU - 0070900644

MÜŞTERİ GRUBU: Tek Terimli Tek Zamanlı Ticarethane OG (Orta Gerilim)

TESİSAT ADRESİ: Son Kaynak Tarifesi Serbesti Tüketicisi

OTOMATİK ÖDEME TALİMATI: GÜLTEPE ÇATALAN 2011/1070 KAMPÜS

FATURA TARİHİ / DÖNEMİ: MERKEZ SARIÇAN ADANA

YOKTUR



e-Arşiv Fatura

Fatura Seri, Sıra No: 3M12018000000248

444 4 372

www.enerjisa.com.tr

ENERJISA TOROSLAR ELEKTRİK PERAKENDE SATIŞ A.Ş.

BAĞLARBAŞI MAH. REFAHİYERLER SOK.

A BLOK NO:2/1 MALTEPE/İSTANBUL

KÜÇÜKYALI V.D. 8560366451

Mersis No: 856036645100015

Tic. Sic. No: 921047

Tel / Faks: (0216) 579 05 00 / (0216) 579 05 30

Web Sitesi: www.toroslarepsas.enerjisa.com.tr

online.enerjisa.com.tr

ORTALAMA TÜKETİM (kWh/gün)

Tarih: 21.12.2017 Sayı: 370



TÜKETİM BİLGİLERİ

	Tek Zaman	Gündüz	Puant	Gece
İlk Endeks		57,314	17,605	23,890
Son Endeks		64,102	19,573	26,612
Endeks Farkı		6,788	1,968	2,722
Çarpan		6.300,000	6.300,000	6.300,000
Aktif Tüketim (kWh)	72.311,400	42.784,400	12.398,400	17.148,600
Ek Tüketim (kWh)				
Trafo Boşta Kaybı (kWh)				
Ek Trafo Boşta Kaybı (kWh)				

REAKTİF TÜKETİM BİLGİLERİ

	Endüktif	Kapasitif	GÜÇ VE GÜÇ AŞIMI
İlk Endeks	4,713	15,021	Sayaç Demand Değeri
Son Endeks	5,909	15,151	Çarpan
Endeks Farkı	1,196	0,130	Demand (Güç)
Çarpan	6.300,000	6.300,000	Anahtama Gücü (kW)
Reaktif Tüketim (kVARh)	7.534,800	819,000	Güç Aşımı
Fatura Edilen Reaktif (kVARh)			Ek Güç
Ek Reaktif Tüketim (kVARh)			Ek Güç Aşımı

REAKTİF TÜKETİM ORANI

BEDELLER

ENERJİ TÜKETİMİ (t) 15.631,34

Tek Zaman Tüketim Bedeli 15.631,34

Gündüz Tüketim Bedeli

Puant Tüketim Bedeli

Gece Tüketim Bedeli

Ek Aktif Tüketim Bedeli

Trafo Boşta Kaybı Bedeli

Ek Trafo Boşta Kaybı Bedeli

(+/-) Tutar

SİSTEM KULLANIM (t) 7.261,29

Dağıtım Bedeli 7.261,29

Güç Bedeli

Ek Güç Bedeli

Güç Aşımı Bedeli

Ek Güç Aşımı Bedeli

Reaktif Bedeli

Ek Reaktif Bedeli

Borçtan K/B Bedeli

DİĞER (t) 0,00

Gecikme Zammı Bedeli (‰140)

Dağıtım Bağlantı Bedeli

Per. Abn. K/B Bedeli

VERGİ/FONLAR (t) 5.596,28

Enerji Fonu 156,31

TRT Payı 312,63

Elektrik ve Havagazı Tüketim Vergisi 781,57

KDV 4.345,77

FATURA TUTARI (t) 28.488,91

Muhtelif Mahsup

Önceki Dönem Yuvarlama Farkı

Yuvarlama Farkı

Damga Vergisi -228,88

YALNIZ YIRMISEKİZBİRDÖRTYÜZSEKSENKİZTLÜKSANBİR

ÖDENECEK TUTAR (t) 28.260,03

KDV MİTRAHİ 24.143,14

SON ÖDEME TARİHİ 19.01.2018

ESKİ BORÇ/BAKİYE (t) 28.161,95

Ödemelerinizi zamanında yaptığınız için teşekkür ederiz.

AKTİF TÜKETİM BİRİM FİYATLARI

	Tek Zaman	Gündüz	Puant	Gece
Tek Zaman Aktif Tüketim	0,21616700			
İndirilmiş Aktif Tüketim				
Ek Aktif Tüketim				
Gündüz Aktif Tüketim				
İndirilmiş Aktif Tüketim				
Ek Aktif Tüketim				
Puant Aktif Tüketim				
İndirilmiş Aktif Tüketim				
Ek Aktif Tüketim				
Gece Aktif Tüketim				
İndirilmiş Aktif Tüketim				
Ek Aktif Tüketim				

SİSTEM KULLANIM BİRİM FİYATLARI

	Tek Zaman	Gündüz	Puant	Gece
Tek Zaman Aktif Tüketim	0,21616700			
İndirilmiş Aktif Tüketim				
Ek Aktif Tüketim				
Gündüz Aktif Tüketim				
İndirilmiş Aktif Tüketim				
Ek Aktif Tüketim				
Puant Aktif Tüketim				
İndirilmiş Aktif Tüketim				
Ek Aktif Tüketim				
Gece Aktif Tüketim				
İndirilmiş Aktif Tüketim				
Ek Aktif Tüketim				

DİĞER BİLGİLER

	80067278/MAKEL	İlk Okuma Tarihi	21.12.2017
Aktif Sayaç Seri No/Marka	80067278/MAKEL	Son Okuma Tarihi	31.12.2017
Endüktif Sayaç Seri No/Marka	80067278/MAKEL	Sonrakı Okuma Dönemi	01.2018
Kapasitif Sayaç Seri No/Marka	80067278/MAKEL	Ort.Tük. (kWh/gün)	6.573,764
Akım Trafo Oranı - Gerilim Trafo Oranı	100,0/ 5,00 - 31.500/ 100,0	Önceki Yıl Tük.(kWh)	694.808,100
Saymanlık Adı	4010887923	Cari Yıl Tük. (kWh)	
Tekil Kod		Sayaç Okuma Birimi	T1120020

MESAJINIZ VAR

Abonelik ve tahliye işlemleriniz için bu belgelere ihtiyac duyabilirsiniz. Eski evi yerine alt tesisat ya da sayaç no, Yeni evi yerine alt tesisat ya da sayaç no, DASK polise no (Yalnızca mesken), Gönence bedeli, Varsa İBAN/Hesapno, Tapu ya da kira kontratı (tüketim noktasında enerji açık ise işlemleri hızlandırır). Yetkilinin nüfus cüzdanı, İy yerine alt evi belgesi ya da vekaletname ve imza sirküleri

Detaylı bilgi: 444 4 372 www.toroslarepsas.enerjisa.com.tr

ETTIN :CE071650-6E02-1E07-B0F3-6346FD5AC9C0



Yatırım ve Menkul Değerler A.Ş.



GARANTİ YATIRIM MENKUL DEĞERLER A.Ş.
Kurum Tev. S.Ş. No: 25520/1300001037



444 81 23

TÜKETİCİ BİLGİLERİ

MÜŞTERİ NO:
MÜŞTERİ NO:
SÖZLEŞME NO:
SÖZLEŞME NO:
TARİHİ NO:
MÜŞTERİ ADI:
MÜŞTERİ ADRESİ:
EĞİTİM DURUMU:
YÜZLÜK NO:
İLAHİ KORDONATÖR NO:
SAP FAKTURA NO:
FATURA TARİHİ:

19/01/2018
T.C. Vatandaşlık ve Menkul Değerler Bakanlığı
19/01/2018
19/01/2018
19/01/2018
19/01/2018
19/01/2018
19/01/2018
19/01/2018
19/01/2018
19/01/2018
19/01/2018

SAYIÇ BİLGİLERİ

19/01/2018
19/01/2018
19/01/2018
19/01/2018
19/01/2018

OKUMA BİLGİLERİ

19/01/2018
19/01/2018
19/01/2018
19/01/2018
19/01/2018

EMİSİYON VE TÜKETİM BİLGİLERİ

19/01/2018
19/01/2018
19/01/2018
19/01/2018
19/01/2018

AKTİF TÜKETİM VE BAKIM FİYATLARI

19/01/2018
19/01/2018
19/01/2018
19/01/2018
19/01/2018

NOTLAR

19/01/2018
19/01/2018
19/01/2018
19/01/2018
19/01/2018

REDELİER

19/01/2018
19/01/2018
19/01/2018
19/01/2018
19/01/2018

ÖDENECEK TUTAR (TL)

96 860.13 TL

SON ÖDEME TARİHİ

19/01/2018

ESKÜ BORÇ/BAKİYE (TL)

19/01/2018

ÖDEME NOKTALARI

19/01/2018



Yedigöcek Elektrik Perakende Satış A.Ş.



E-ARŞİV FATURA
Fatura Seri, Sıra No:
YE52018000041398



444 55 23

1. TUKETİCİ BİLGİLERİ

MÜŞTERİ NO: 5000411018
MÜŞTERİ GRUBU: Tek Terimli Tek Zamanlı Ticarethane OG
SÖZLEŞME NO: 5500480200
SÖZLEŞME HESABI: 4002423982
TESİSAT NO: 4201990471
MÜŞTERİ ADI: ADANA BİLİM VE TEKNOLOJİ ÜNİVERSİTESİ İD
MÜŞTERİ ADRESİ: GÜLTEPE MAH. ÇATALAN CD. NO: 291 B.TÜ
KAMPÜS SARIÇAM Adana
VERGİ DAİRESİ: ZİYAPASA
TC VERGİ NO: 3070600641
İL KOORDİNATÖRLÜĞÜ: Adana
SAP FATURA NO: YB 011003077767
FATURA TARİHİ: 31.07.2018 17:59

YEPAŞ
CUMHURİYET MAH. ATATÜRK BULV.
C/Ç 308-310 - 52060 ÇATALAN - SAMSUN /
TÜRKİYE
GİZLİLER: 2350558299
Tel: 0362 311 50 26 Faks: 0362 995 29 78
Yazma No: 230655829900019
İletişim: ATAKUM
Web Sitesi: www.yesilimakepas.com

2. SAYAÇ BİLGİLERİ

Aktif Sayaç Marka / Seri No: MAKEL / 80087278
Endüktif Sayaç Marka / Seri No: MAKEL / 80087278
Kapasitif Sayaç Marka / Seri No: MAKEL / 80087278
Demand Sayaç Marka / Seri No: MAKEL / 80087278

3. OKUMA BİLGİLERİ

İlk Okuma Tarihi: 01.07.2018
Son Okuma Tarihi: 31.07.2018
Fatura Dönemi: 07.2018
Sonraki Okuma Dönemi: 08.2018
Kurulu Güç: 4800,000
Günlük Ort. Tuk. (kWh/gün): 8168,458
Akım Trf. Oran: 01870010
Sayaç Okuma Birimi: Ekip
Geri Dön. Trf. Oran:

4. İNDEKS VE TÜKETİM BİLGİLERİ

	Aktif (kWh)	Gündüz (kWh)	Pasant (kWh)	Gece (kWh)	Endüktif (kVarh)	Kapasitif (kVarh)	Demand
İlk Endeksi	279,435	171,093	44,170	64,162	13,824	21,279	
Son	315,829	199,499	49,414	70,726	15,046	21,978	
Endeksi	315,829	199,499	49,414	70,726	15,046	21,978	
Çarpan	6300,000	8300,000	6300,000	6300,000	8300,000	6300,000	
Tüketim	253222,200	179461,800	53037,300	40723,100	7638,400	4433,700	

5. AKTİF TÜKETİM VE BİRİM FİYATLARI

	Tüketim	Ek Tüketim	Birim Fiyat	Toplam Tutar
Tek Zaman Aktif Tüketim	253222,200	0,000	0,243747	61.722,26 TL
Dağılım Bedeli	253222,200	0,000	0,163253	27.855,29 TL
Reaktif Tutar	0,000	0,000	0,000000	0,00 TL

6. NOTLAR

Tamamı Sanatçılar Anlaşma
Tasahhütü sona erime tarihi: 31.12.2018.
Tasahhüt süresi 11 aydır. Tasahhütümüzün 7. ayındadır.

Önceki Yıl Tüketim: 0,000 kWh
Çan Yıl Tüketim: 1319,854,000 kWh
Tüketim No: TR-001-1000000000

e-Argiv sistemi kapsamında elektronik ortamda teslim edilmiştir.

BTÜH: AA18PD08-ED02-IED8-A888-4882FABE3205
Fatura Tutarı YÜZ KIRK BİR DÖRT YÜZ ON TL BEKSEYYEDİ Kış. İst.

7. BEDELLER

DİĞER İŞİ
Tutar Fiyat Farkı Tutarı: 24.667,00 TL

8. VERGİLERİ

Elektrik Tuk. Ver: 3,086,11 TL
TRT Fonu Tutarı: 1,224,44 TL
Enerji Fonu Tutarı: 617,22 TL

TOPLAM TUTAR: 118.992,26 TL
KDV: 21.418,81 TL

FATURA TUTARI: 140.410,87 TL
Multipl Mahsup: 0,00 TL
Önceki Dönem Yaratılma: 0,00 TL
Farkı: 0,00 TL
Tutarlama Farkı: 0,00 TL
Damga Vergisi: 1128,85 TL

ÖDENECEK TUTAR (İ)

139.282,82 TL

Elektrik faturalarımız www.gpdik.gov.tr adresinden kontrol edebilirsiniz.

SON ÖDEME TARİHİ: 15.08.2018

ESKİ BORÇ/BAKİYET: 0

ÖDEME NOKTALARI

YEPAŞ Vezne Anlaşım Bankalar NW ile çalışmamızla

MÜŞTERİ BİLGİLERİ

ADANA SİTİ KENTİ YOLU
T.C. SİTİ KENTİ YOLU
MÜŞTERİ ADI
MÜŞTERİ ADRESİ
MÜŞTERİ ADRESİ
MÜŞTERİ ADRESİ

1018937319
401087723
30307094
ADANA BİLİM VE TEKNOLOJİ ÜNİVERSİTESİ
İDARE VE MALİYE DİREKTÖRLÜĞÜ
ZİYAPASA YOLU - 0108010000
Trafik, Tesisat, Tesisat, Tesisat, Tesisat
Güç, Tesisat, Tesisat, Tesisat, Tesisat
GÜLİPE MAH. ÇATALAN CD. NO:201481
KAMPUS
MERKEZ SARIÇAM ADANA
YOKTUR
31.10.2018 22:59 Ekim 29'la



e-Arşiv Fatura

Fatura Seri: 3E22018000002762

ENERJİSA ÇAĞRI MERKEZİ

ENERJİSA TOROSLAR ELEKTRİK PERAKENDE SATIŞ A.Ş.
BAĞLARBAŞI MAH. REFAHİYERLER SOK.
A BLOK NO:2/1 MALTEPE/İSTANBUL
KÜÇÜKYALI V.D. 8560366451

Mersis No : 0856036645100015
Tic. Sic. No : 221947
Tel / Fax : (0216) 579 05 00 / (0216) 579 05 30
Web Sitesi : www.toroslarpsas.enerjisa.com.tr
online.enerjisa.com.tr

ORTALAMA TÜKETİM (kWh/gün)

2017
2018

Ocak Şubat Mart Nisan Mayıs Haziran Temmuz Ağustos Eylül Ekim Kasım Aralık

TÜKETİM BİLGİLERİ Tek Zaman Gündüz Pknt Gece

İlk Endeks	246.710	58.470	82.924
Son Endeks	263.072	62.560	88.977
Endeks Farkı	16.362	4.030	6.053
Çarpan	6.300.000	6.300.000	6.300.000
Aktif Tüketim (kWh)	166.603.500	101.060.000	38.133.399
Ek Tüketim (kWh)			
Trafo Boşta Kaybı (kWh)			
Ek Trafo Boşta Kaybı (kWh)			

REAKTİF TÜKETİM BİLGİLERİ

Endüktif	Kapasitif	GÜÇ VE GÜÇ AŞIMI
İlk Endeks	17.567	23.041
Son Endeks	18.223	23.740
Endeks Farkı	0.656	0.699
Çarpan	6.300.000	6.300.000
Reaktif Tüketim (kVARh)	4.132.800	4.463.780
Fatura Edilen Reaktif (kVARh)		
Ek Reaktif Tüketim (kVARh)		
REAKTİF TÜKETİM ORANI		

AKTİF TÜKETİM BİRİM FİYATLARI

Tek Zaman	Gündüz	Pknt	Gece
Tek Zaman Aktif Tüketim	0.42682500		
İndirimli Aktif Tüketim			
Ek Aktif Tüketim			
Gündüz Aktif Tüketim			
İndirimli Aktif Tüketim			
Ek Aktif Tüketim			

PUANT AKTİF TÜKETİM BİRİM FİYATLARI

Tek Zaman	Gündüz	Pknt	Gece
Tek Zaman Aktif Tüketim			
İndirimli Aktif Tüketim			
Ek Aktif Tüketim			

GECE AKTİF TÜKETİM BİRİM FİYATLARI

Tek Zaman	Gündüz	Pknt	Gece
Tek Zaman Aktif Tüketim			
İndirimli Aktif Tüketim			
Ek Aktif Tüketim			

İNDİRİM ORANI

Diğer Bilgiler

Aktif Sayı Seri No/Marka	80087278/MAKEL	İlk Okuma Tarihi	12.10.2018
Endüktif Sayı Seri No/Marka	80087278/MAKEL	Son Okuma Tarihi	31.10.2018
Kapasitif Sayı Seri No/Marka	80087278/MAKEL	Sonrakı Okuma Dönemi	11.2018
Akım Trafosı Oranı-Görünüm Trafosı Oranı	100.0/5.00-31.500-100.0	Ort. Tük. (kWh/gün)	8.330.175
Saymanlık Adı		Önceki Yıl Tük.(kWh)	594.886.106
Tekil Kod	4010887923	Carı Yıl Tük.(kWh)	1.516.850.600
		Sayı Okuma Birimi	T1120030

ÖNECEK Tutar (₺)

112.188,69

VERGİLER TOPLAMI: 22.940,98

KDV MATRAHI: 95.845,17

SON ÖDEME TARİHİ: 14.11.2018

ESKİ BORÇ/BAKİYE (₺): 0,00

Ödemeleri zamanında yaptığınız için teşekkür ederiz.

ETTN: 0AB6F732-CE92-1EE8-B88A-607C16E8D0ACD

ENERJİSA

HESAP NO
1014807819
4010887923
208334564

AD SOYADI
ADANA BİLİM VE TEKNOLOJİ ÜNİVERSİTESİ
İÇİŞİ VE MALİ İŞLER DAİRE BAŞKANLIĞI
ZYAPASA YD - 0070600644

TEK TARAFLI
Tek Tarihli Tek Zamanlı Tisarethane OG Orta Gerilim/Son Kaynak Tarifesi Serbest

TEBİSAT ADRESİ
TÜRKİYE
GÜLTEPE MAH. ÇATALAN CD. NO:261 1B1Ü
KAMPÜS
MERKEZ SARIÇAM ADANA
YOKTUR

OTOMATİK ÖDEME TALİMATI
FATURA TARİHİ / DÖNEMİ
31.12.2018 20.09 / Aralık 2018



e-Arşiv Fatura

444 4 372
www.enerjisa.com.tr

ENERJİSA TOROSLAR ELEKTRİK PERAKENDE SATIŞ A.Ş.
BAĞLARBAŞI MAH. REFAHİEVLER SOK.
A BLOK NO:2/1 MALTEPE/İSTANBUL
KÜÇÜKYALI V.D. 8560366451

Mersis No : 0856036645100015
Tic. Sic. No : 321047
Tel / Fax : (0216) 579 05 90 / (0216) 579 05 30
Web Sitesi : www.toroslarpsas.enerjisa.com.tr
: online.enerjisa.com.tr

ORTALAMA TÜKETİM (kWh/gün)

TÜKETİM BİLGİLERİ

	Tek Zaman	Gündüz	Puant	Gece
İlk Endeks		280,371	66,882	95,595
Son Endeks		306,982	72,550	103,913
Endeks Farkı		25,711	5,668	8,318
Çarpan		6,300,000	6,300,000	6,300,000
Aktif Tüketim (kWh)	250,028,100	161,979,300	35,645,400	52,403,400
Trafo Boşta Kaybı (kWh)				

REAKTİF TÜKETİM BİLGİLERİ

	Endüktif	Kapasitif	GÜÇ VE GÜÇ AŞIMI
İlk Endeks	18,723	24,413	Sayaç Demand Değeri
Son Endeks	19,841	25,153	Çarpan
Endeks Farkı	1,118	0,740	Demand (Güç)
Çarpan	6,300,000	6,300,000	Anlaşma Gücü (kW)
Reaktif Tüketim (kVARh)	7,043,400	4,662,000	Güç Aşımı
Fatura Edilen Reaktif (kVARh)			Ek Güç
Ek Reaktif Tüketim (kVARh)			Ek Güç Aşımı

AKTİF TÜKETİM BİRİMİ FİYATLARI

	Tek Zaman	Gündüz	Gece
Tek Zaman Aktif Tüketim	0,42682500		
İndirimli Aktif Tüketim			
Ek Aktif Tüketim			
Gündüz Aktif Tüketim			
İndirimli Aktif Tüketim			
Ek Aktif Tüketim			
Puant Aktif Tüketim			
İndirimli Aktif Tüketim			
Ek Aktif Tüketim			
Gece Aktif Tüketim			
İndirimli Aktif Tüketim			
Ek Aktif Tüketim			

İNDİRİM ORANI

BEDELLER

ENERJİ TÜKETİMİ (kWh) 106.718,24

Tek Zaman Tüketim Bedeli 106.718,24

Gündüz Tüketim Bedeli

Puant Tüketim Bedeli

Gece Tüketim Bedeli

Ek Aktif Tüketim Bedeli

Trafo Boşta Kaybı Bedeli

Ek Trafo Boşta Kaybı Bedeli

(+/-) Tutar

SİSTEM KULLANIM (%) 28.582,71

Dağıtım Bedeli 28.582,71

Güç Bedeli

Ek Güç Bedeli

Güç Aşımı Bedeli

Ek Güç Aşımı Bedeli

Reaktif Bedeli

Ek Reaktif Bedeli

Borçtan K/B Bedeli

Diğer (₺) 0,00

OKUMA BİLGİLERİ

	Okuma Tarihi	Okuma Birimi
Aktif Sayaç Seri No/Marka	80087278/MAKEL	01.12.2018
Endüktif Sayaç Seri No/Marka	80087278/MAKEL	31.12.2018
Kapasitif Sayaç Seri No/Marka	80087278/MAKEL	01.2019
Akım Trafo Oranı-Gerilim Trafo Oranı	100,0/ 5,00-31.500/ 100,0	8,065,423
Saymanlık Adı	4010887923	2,345,225,480
Tekil Kod		T1120630

VERGİ/FONLAR (₺) 34.428,36

Enerji Fonu 1.057,18

TRT Payı 2.134,36

Elektrik ve Hava Gazı Tüketim Vergisi 5.335,91

KDV 25.890,91

FATURA TUTARI (₺) 169.729,31

Muhtelif Mahsup

Önceki Dönem Yuvarlama Farkı

Yuvarlama Farkı -0,01

Damga Vergisi

ÖDENECEK TUTAR (₺) 169.729,30

Elektronik fatura olarak bu belgeyi adresinizden kontrol edebilirsiniz
e-Arşiv izni kapsamında elektronik ortamda habittir.

VERGİLER TOPLAMI: 34.428,36

KDV MATRAHI: 143.838,40

SON ÖDEME TARİHİ 14.01.2019

ESKİ BORÇ/BAKİYE (₺) -511,46

Ödemeleri zamanında yaptığınız için teşekkür ederiz.

ETTIN: 0AB6F732-CE02-1EE9-83D6-267A0ECC444E

ERİ BİLGİLERİ
EŞİME HESAP NO
HESAP NO
MÜŞTERİ ADI
VERGİ DAİRESİ - VİDİ / TCKN
TÜKETİCİ GRUBU

1010887919
4010887923
209934564
ADANA BİLİM VE TEKNOLOJİ ÜNİVERSİTESİ İDARİ VE MALİ İŞLER DAİRESİ BAŞKANLIĞI
ZYAPASA YD - 0670600644
Cih Tarifi: Tek Zamanlı Ticarethane OG (Orta Gerilim)
San Kaynak Tarifesi Serbest Tüketici
GÜLTEPE MAH. ÇATALAN CD. NO:201/1000 KAMPÜS
MERKEZ SARÇAM ADANA
YOKTUR
31.03.2019 23:59:59 2019

e-Arsiv Fatura

Fatura Sıra No: 3E22019000002209

ENERJİSA TOROSLAR ELEKTRİK PERAKENDE SATIŞ A.Ş.
Barbaros Mah. Begonya Sok. Nida Kule
Ataşehir Satış Ofisi No: 41/ Ataşehir / İstanbul
Kazıyolu Y.D. 856 820 6491

Bilanço No : 0096 6366 4510 0018
Tic. Sic. No : 821047
Tel / Faks : (0216) 579 05 00 / (0216) 579 05 39
Web Sitesi : enerjisa.com.tr
toroslar@enerjisa.com

OTOMATİK ÖDEME TALANATI
FATURA TARİHİ / DÖNEMİ

ORTALAMA TÜKETİM (kWh/gün)



TÜKETİM BİLGİLERİ	Tek Zaman	Gündüz	Puant	Gece
İlk Endeks		361,722	83,618	119,753
Son Endeks		383,862	88,461	127,762
Endeks Farkı		22,130	4,843	8,009
Ortalama Tüketim (kWh)	220,386,600	139,419,000	30,510,900	50,456,700
Ek Tüketim (kWh)				
Trafo Boşta Kaybı (kWh)				
Ek Trafo Boşta Kaybı (kWh)				

REAKTİF TÜKETİM BİLGİLERİ	Endüktif	Kapasitif	GÜÇ VE GÜÇ AŞIMI
İlk Endeks	22,176	26,682	Sayış Demand Değeri: 0,160
Son Endeks	23,242	27,294	Çarpan: 8,300,000
Endeks Farkı	1,066	0,612	Demand (Güç): 1,008,000
Çarpan	8,300,000	6,300,000	Anlaşma Gücü (kW): 1,450,000
Reaktif Tüketim (kVARh)	6,703,200	3,855,600	Güç Aşımı
Fatura Edilen Reaktif (kVARh)			Ek Güç
Ek Reaktif Tüketim (kVARh)			Ek Güç Aşımı

AKTİF TÜKETİM BİRİM FİYATLARI		SİSTEM KULLANIM BİRİM FİYATLARI	
		0,40657900	
Tek Zaman Aktif Tüketim		Dağıtım	0,10601400
İndirilmiş Aktif Tüketim		Güç	2,58859700
Ek Aktif Tüketim		Ek Güç	
		Güç Aşımı	
Gündüz Aktif Tüketim		Ek Güç Aşımı	
İndirilmiş Aktif Tüketim		Endüktif Reaktif	
Ek Aktif Tüketim		Kapasitif Reaktif	
		Ek Reaktif	
		Trafo Boşta Kaybı	
		Ek Trafo Boşta Kaybı	
Puant Aktif Tüketim			
İndirilmiş Aktif Tüketim			
Ek Aktif Tüketim			
Gece Aktif Tüketim			
İndirilmiş Aktif Tüketim			
Ek Aktif Tüketim			

DİĞER BİLGİLER		OKUMA BİLGİLERİ	
Aktif Sayış Seri No/Marka	80087278/MAKEL	İlk Okuma Tarihi	01.03.20
Endüktif Sayış Seri No/Marka	80087278/MAKEL	Son Okuma Tarihi	31.03.20
Kapasitif Sayış Seri No/Marka	80087278/MAKEL	Sonrakı Okuma Dönemi	04.20
Alım Trafosu Oranı - Gerilim Trafosu Oranı	100,0/5,0-31,500/100,0	Ort.Tük. (kWh/gün)	7.106,24
Sayışmanlık Adı		Önceki Yıl Tük(kWh)	2.345.225,40
Tekil Kod	4010887923	Cari Yıl Tük (kWh)	740.439,00
		Sayış Okuma Birimi	T1120030

MESAJINIZ VAR

BEDELLER	
ENERJİ TÜKETİMİ (₺)	89.604,56
Tek Zaman Tüketim Bedeli	89.604,56
Gündüz Tüketim Bedeli	
Puant Tüketim Bedeli	
Gece Tüketim Bedeli	
Ek Aktif Tüketim Bedeli	
Trafo Boşta Kaybı Bedeli	
Ek Trafo Boşta Kaybı Bedeli	
(+/-) Tutar	

SİSTEM KULLANIM (₺)	27,086,54
Elk. Dağıtım Bedeli	23,364,07
Güç Bedeli	3,724,47
Ek Güç Bedeli	
Güç Aşımı Bedeli	
Ek Güç Aşımı Bedeli	
Reaktif Bedeli	
Ek Reaktif Bedeli	
Borçtan KIB Bedeli	

DİĞER (₺)	0,00
-----------	------

VERGİ/FONLAR (₺)	26,463,43
Enerji Fonu	896,05
TRT Payı	1,792,09
Elektrik ve Hava Gazı Tüketim Vergisi	4,480,23
KDV	22,295,06

FATURA TUTARI (₺)	146,156,53
Muhtelif Mahsup	
Önceki Dönem Yuvarlama Farkı	
Yuvarlama Farkı	
Damga Vergisi	-1,174,21

YALNIZ YÜZKURKALTI/BİNYÜZELLİALİTİLELİÜÇK

ÖDENECEK TUTAR (₺)	144,982,32
--------------------	------------

Ödellenen tutarlar...
e-Arsiv izni kapsamında elektronik ortamda iletilmiştir.

VERGİLER TOPLAMI:	29,463,43
KDV MATRAHI:	123,861,47

SON ÖDEME TARİHİ 12.04.2019

ESKİ BORÇ/BAKİYE (₺) -511,46

Ödemelerinizi zamanında yaptığınız için teşekkür ederiz.



e-Arşiv Fatura

BİLGİLERİ

YALINIZ YÜZONBEŞBİ NYEDİYÜZYİRMİYEDİTL/EDİKR
ÖDENECEK TUTAR (₺)
114.797,33

1010157718
4010157702
2019124164
ADANA BİLM VE TETAYODUĞU İNDİREKTEKİ
ÇARŞI VE MAİL BİLER DÖRE BAKANLAR
777 APARSA YOLU 01010000044
C.H. İndirimi Tek Çarşısı Tutarı: 00,00 TL
Bilgi: Ser. Kağıtın Tutarı: 00,00 TL
Tutar: 0 TL
C.H. İNDİRİMİ MAİL BİLER DÖRE BAKANLAR
KAPUSU
MERKEZ, SAKIÇAM ADANA
YOKTUR
20.04.2019 10:10:10 - Nispet 2019

Fatura Sayısı No: 3E22019000003293

ENERJİSA TOROSLAR ELEKTRİK PERAKENDE SATIŞ A.Ş.
Barbaros Mah. Bagonya Ser. Nide Akın Akayınz Bul. 8.2
No 111 Atayahır - İstanbul
Kocayatağı V.D. 0500360451

Mersis No: 0836030045100010
Tic. Sic. No: 2921047
Tel / Fax: (0216) 578 15 00 / (0216) 578 15 30
Web Sitesi: enerjisa.com.tr
toroslarapasa.enerjisa.com

ORTALAMA TÜKETİM (kWh/gün)



TÜKETİM BİLGİLERİ

Tek Zaman	Gündüz	Puant	Gece
İlk Endeks	383.852	88.461	127.782
Son Endeks	401.375	92.504	134.548
Endeks Farkı	16.523	4.043	6.767
Çarpan	6.300.000	6.300.000	6.300.000
Aktif Tüketim (kWh)	172.323.900	164.064.900	42.758.100
Ek Tüketim (kWh)			
Trafo Boşta Kaybı (kWh)			
Ek Trafo Boşta Kaybı (kWh)			

REAKTİF TÜKETİM BİLGİLERİ

Endüksiyon	Kapasite	GÜÇ VE GÜÇ AŞIMI
İlk Endeks	23.242	Sayış Demand Değeri
Son Endeks	24.112	Çarpan
Endeks Farkı	0.870	Demand (Güç)
Çarpan	6.300.000	Anlaşım Gücü (kV)
Reaktif Tüketim (kVARh)	5.481.000	Güç Aşımı
Fatura Edilen Reaktif (kVARh)	3.887.100	Ek Güç
Ek Reaktif Tüketim (kVARh)		Ek Güç Aşımı
REAKTİF TÜKETİM ORANI		

AKTİF TÜKETİM BİRİM FİYATLARI

Tek Zaman	Gündüz	Puant	Gece
Tek Zaman Aktif Tüketim	0,39571200	Dağıtım	0,11775000
İndirilmiş Aktif Tüketim		Güç	2,65293800
Ek Aktif Tüketim		Ek Güç	
		Güç Aşımı	
		Ek Güç Aşımı	
		Endüksiyon Reaktif	
		Kapasite Reaktif	
		Ek Reaktif	
		Trafo Boşta Kaybı	
		Ek Trafo Boşta Kaybı	

GECE AKTİF TÜKETİM BİRİM FİYATLARI

Tek Zaman	Gündüz	Puant	Gece
Tek Zaman Aktif Tüketim	0,39571200	Dağıtım	0,11775000
İndirilmiş Aktif Tüketim		Güç	2,65293800
Ek Aktif Tüketim		Ek Güç	
		Güç Aşımı	
		Ek Güç Aşımı	
		Endüksiyon Reaktif	
		Kapasite Reaktif	
		Ek Reaktif	
		Trafo Boşta Kaybı	
		Ek Trafo Boşta Kaybı	

İNDRİM ORANI

Tek Zaman	Gündüz	Puant	Gece
Tek Zaman Aktif Tüketim	0,39571200	Dağıtım	0,11775000
İndirilmiş Aktif Tüketim		Güç	2,65293800
Ek Aktif Tüketim		Ek Güç	
		Güç Aşımı	
		Ek Güç Aşımı	
		Endüksiyon Reaktif	
		Kapasite Reaktif	
		Ek Reaktif	
		Trafo Boşta Kaybı	
		Ek Trafo Boşta Kaybı	

OKUMA BİLGİLERİ

Tek Zaman	Gündüz	Puant	Gece
Tek Zaman Aktif Tüketim	0,39571200	Dağıtım	0,11775000
İndirilmiş Aktif Tüketim		Güç	2,65293800
Ek Aktif Tüketim		Ek Güç	
		Güç Aşımı	
		Ek Güç Aşımı	
		Endüksiyon Reaktif	
		Kapasite Reaktif	
		Ek Reaktif	
		Trafo Boşta Kaybı	
		Ek Trafo Boşta Kaybı	

MESALİM VAR

ETT: 94B6F732-CE02-1ED9-3B9C-86879915D710

BEDELLER

Tek Zaman Tüketim Bedeli	68.190,64
Gündüz Tüketim Bedeli	68.190,64
Puant Tüketim Bedeli	
Gece Tüketim Bedeli	
Ek Aktif Tüketim Bedeli	
Trafo Boşta Kaybı Bedeli	
Ek Trafo Boşta Kaybı Bedeli	
(+) Tutar	

SİSTEM KULLANIM BİRİM FİYATLARI

Ek Dağıtım Bedeli	20.291,14
Güç Bedeli	4.136,76
Ek Güç Bedeli	
Güç Aşımı Bedeli	
Ek Güç Aşımı Bedeli	
Reaktif Bedeli	
Ek Reaktif Bedeli	
Borçlan K/B Bedeli	

İNDRİM

İNDRİM	0,00
--------	------

VERGİLER

Enerji Fonu	881,91
TRT Payı	1.363,91
Elektrik ve Havagazı Tüketim Vergisi	3.406,53
KDV	17.653,28

FATURA TUTARI

Muhtelif Mahsup	
Önceki Dönem Yuvarlama Farkı	
Yuvarlama Farkı	
Damga Vergisi	-929,74

YALINIZ YÜZONBEŞBİ NYEDİYÜZYİRMİYEDİTL/EDİKR

ÖDENECEK TUTAR (₺)

114.797,33

Bu fatura, Enerjisa ÇAĞRI MERKEZİ'nde elektronik ortamda iletilecektir.
e-Arşiv 2019 yılında kapsamlı olarak elektronik ortamda iletilecektir.

VERGİLER TOPLAMI

23.108,53

KDV MATRAHI

98.073,79

SON ÖDEME TARİHİ

13.05.2019

ESKİ BORÇ/BAKIYE (₺)

-511,46

Ödeme tarihi 2019-05-13 tarihine kadar geçerlidir.

İŞİ BİLGİLERİ

ESKİ HESAP NO: 1916397912
 İSTATİ NO: 441933723
 İSTİFRADE EYAN: 31934344
 VERGİ DAİRESİ YENİ TÜR: ADANA EKİM 15 TEZKİLO İÇİŞİLERİ
 VERGİ DAİRESİ YENİ TÜR: DANIŞMANLIK İŞİ DAİRESİ BAŞKANLIĞI
 VERGİ DAİRESİ YENİ TÜR: ZİYAPASA 98 50790344
 VERGİ DAİRESİ YENİ TÜR: ÇİTİME Tek Zamanlı Tesisatları 00 (00)
 VERGİ DAİRESİ YENİ TÜR: GERMİŞÖN Kaynak Tesisatları (00)
 VERGİ DAİRESİ YENİ TÜR: TİCARET
 VERGİ DAİRESİ YENİ TÜR: GÜÇLÜPE NAKİT İSTATİSİ CO NO 0011027
 VERGİ DAİRESİ YENİ TÜR: KAMPUS
 VERGİ DAİRESİ YENİ TÜR: MERKEZ SAKIÇAM ADANA
 VERGİ DAİRESİ YENİ TÜR: YOKTUR
 VERGİ DAİRESİ YENİ TÜR: 00 19 2019 21 00 19 00 10 10

TEKZAT ADRESİ

ÖZGÜR SAĞLAM (TUTANAK)
 FATURA TARİHİ: 12.07.2019



e-Arşiv Fatura

ENERJİSA TOROSLAR ELEKTRİK PERAKENDE SATIŞ A.Ş.
 Sarıpaşa Mah. Beğonya Sok. N:1 da Kuvva Alayına Bina 30.
 No:111 Atayehi İstanbul
 Kızılay Y.D. 356036451

Merkezi No: 0855 0306 4511 0015
Tic. Sic. No: 291047
Yat. / Fax: 0312 573 96 00 / 0312 573 96 00
Web Sitesi: enerjisa.com.tr
 toroslar@enerjisa.com.tr

ORTALAMA TÜKETİM (kWh/gün)

TÜKETİM BİLGİLERİ

	Tek Zaman	Gündüz	Puant	Gece
İlk Endeks	416.550	36.288	140.796	
Son Endeks	438.040	100.100	146.796	
Endeks Farkı	19.510	3.812	8.093	
Çarpan	6.300.000	6.300.000	6.300.000	
Aktif Tüketim (kWh)	123.314.500	122.913.000	24.015.600	36.385.900
Ek Tüketim (kWh)				
Trafo Boşta Kaybı (kWh)				
Ek Trafo Boşta Kaybı (kWh)				

REAKTİF TÜKETİM BİLGİLERİ

	Endüktif	Kapasitif	II. GÜÇ VE GÜÇ AŞIMI
İlk Endeks	24.538	28.799	Saygı Demand Değeri 0.168
Son Endeks	25.697	29.482	Çarpan 6.300.000
Endeks Farkı	1.159	0.713	Demand (Güç) 1.958.400
Çarpan	6.300.000	6.300.000	Anlagım Gücü (kW) 1.450.000
Reaktif Tüketim (kVARh)	7.301.700	4.491.900	Güç Aşımı
Fatura Edilen Reaktif (kVARh)			Ek Güç
Ek Reaktif Tüketim (kVARh)			Ek Güç Aşımı

AKTİF TÜKETİM BİRİM FİYATLARI

	0.39571200	0.11775000
Tek Zaman Aktif Tüketim		
İndirimli Aktif Tüketim		
Ek Aktif Tüketim		
Gündüz Aktif Tüketim		
İndirimli Aktif Tüketim		
Ek Aktif Tüketim		
Puant Aktif Tüketim		
İndirimli Aktif Tüketim		
Ek Aktif Tüketim		
Gece Aktif Tüketim		
İndirimli Aktif Tüketim		
Ek Aktif Tüketim		

İNDİRİM ORANI

BEDELLER

ENERJİ TÜKETİMİ (I) 73.331,17

Tek Zaman Tüketim Bedeli 73.331,17

Gündüz Tüketim Bedeli

Puant Tüketim Bedeli

Gece Tüketim Bedeli

Ek Aktif Tüketim Bedeli

Trafo Boşta Kaybı Bedeli

Ek Trafo Boşta Kaybı Bedeli

(+/-) Tutar

SİSTEM KULLANIM (II) 25.957,54

Ek Dağıtım Bedeli 21.820,78

Güç Bedeli 4.136,76

Ek Güç Bedeli

Güç Aşımı Bedeli

Ek Güç Aşımı Bedeli

Reaktif Bedeli

Ek Reaktif Bedeli

Borçtan KB Bedeli

DİĞER (III) 0,00

VERGİ FONLARI (IV) 24.794,43

Enerji Fonu 733,31

TRT Payı 1.466,82

Elektrik ve Havagazı Tüketim Vergisi 3.666,56

KDV 18.927,94

FATURA TUTARI (V) 124.083,14

Muhtelif Mahsup

Önceki Dönem Yıvırlama Farkı

Yıvırlama Farkı

Damga Vergisi -995,87

YALNIZ YÜZ YİRMİ DÖRT BİN SEKSEN ÜÇ Lİ ON DÖRT TL

ÖDENECEK TUTAR (VI)

123.086,27

Etiler Elektrik Enerji A.Ş. Etiler Elektrik Enerji A.Ş. Etiler Elektrik Enerji A.Ş.

e-Arşiv izni kapsamında elektronik ortamda iletilmiştir.

VERGİLER TOPLAMI 24.794,43

KDV MATRAHI 106.155,20

SON ÖDEME TARİHİ 12.07.2019

ESKİ BORÇ/BAKİYE (VII) -511,46

Ödemeleri zamanında yaptığınız için teşekkür ederiz.

İN: 22809C00-4402-1ED9-A75E-BEC66138001

MÜŞTERİ BİLGİLERİ

ÖLÇME HESAP NO : 1016907919
 FAT NO / TEKİL KOD : 4010887923
 SERİ NO : 208934564
 MÜŞTERİ ADI SOYADI : ADANA BİLİM VE TEKNOLOJİ ÜNİVERSİTESİ
 İDARI VE MALİ İŞLER DAİRE BAŞKANLIĞI
 ZİYAPASA VD : 0070600644
 ERGİ DAİRESİ - VKN : Çift Terimli Tek Zamanlı Ticarethane OG (Orta Gerilim) / Son Kaynak Tarifesi Serbest Tüketicisi
 TUKETİCİ GRUBU : GÜLTEPE MAH. CATALAN CD. NO:201/1/BTÜ KAMPUS MERKEZ SARICAM ADANA
 TESİSAT ADRESİ :
 OTOMATİK ÖDEME TALİMATI : YOKTUR
 FATURA DÖNEMİ / TARİHİ : Temmuz 2019 / 31.07.2019 23:59



e-Arsiv Fatura

Fatura Seri No: 3E22019000007137

ENERJİSA TOROSLAR ELEKTRİK
 PERAKENDE SATIŞ A.Ş.
 Barbaros Mah. Begonya Sok. Nika Kule
 Ataşehir Batı Sit. No: 1/1 Ataşehir / İstanbul
 Kozyatağı V.D. 856 036 6451

Mersis No : 0856 0366 4510 0015
 Tic Sic No : 921047
 Tel : (0216) 579 05 00
 Faks : (0216) 579 05 30
 Web Sitesi : enerjisa.com.tr
 toroslarepsas.enerjisa.com

ORTALAMA TÜKETİM (kWh/gün)



TÜKETİM BİLGİLERİ VE BEDELLERİ

İNDEKS BİLGİLERİ	İLK ENDEKS	SON ENDEKS	FARK
Tek Zaman			15,818
Gündüz	0,008	11,338	11,330
Puant	0,000	1,856	1,856
Gece	0,000	2,632	2,632
Endüktif	0,000	0,398	0,398
Kapasitif	0,000	0,375	0,375

ENERJİ BİLGİLERİ	TÜKETİM	BİRİM FİYAT	BEDEL (TL)
Tek Zaman	99.653,400	0,46396800	46.235,99
Ek Aktif Tük. Tek Zaman	132.608,700	0,46396800	61.526,19
AKTİF TOPLAM	232.262,100		107.762,18
Elek. Dağıtım	232.262,100	0,12640100	29.358,16
Güc	1.450,000	3,06255500	4.440,70
SİSTEM KUL. TOPLAM			33.798,86
TOPLAM			141.561,04

ÖZET BİLGİLER

Enerji Bedelleri Toplamı	141.561,04
Vergi / Fonlar Toplamı	35.653,73
FATURA TUTARI	177.214,77

YALNIZ YÜZETMİSYEDİBİNİKİYUZONDÖRTTLİYETMİSYEDİKR

Damga Vergisi	1.423,73
ÖDENECEK TUTAR	175.791,04
SON ÖDEME TARİHİ	15.08.2019
ESKİ BORÇ / BAKİYE (TL)	- / -

Ödemelerinizi zamanında yaptığınız için teşekkür ederiz.

e-Arsiv izni kapsamında elektronik ortamda iletilmiştir.

SAYAÇ VE OKUMA BİLGİLERİ

İlk / Son Okuma Tarihi	01.07.2019 / 31.07.2019
Okuma Gün Farkı	31
Sonraki Okuma Dönemi	08.2019
Sayac Okuma Birimi	T112D030
Akt / End / Kap Sayac Marka / Tip / Seri No	LUNA / 67494682
Akım - Gerilim Trafo Oranı	100 / 5 : 31.500 / 100
Sayac Demand Değeri / Anl. Gücü	957,600 / 1.450,000
Çarpan	6.300,000
ETSO/EIC	40Z000047453442Q

TÜKETİMLERİNİZ (kWh/gün)

DÖNEM	TOPLAM	GÜNLÜK ORTALAMA
2018	2.345.225,400 (kWh)	6.643,698 (kWh/gün)
2019	1.494.744,300 (kWh)	7.117,830 (kWh/gün)

MESAJINIZ VAR

DİĞER

BEDEL (TL)

VERGİ / FONLAR	BEDEL (TL)
Enerji Fonu	1.077,62
TRT Payı	2.155,24
Elekt. ve Hvg. Tük. Ver.	5.388,11
KDV %18 (Matrah: 150.182,01 TL)	27.032,76
TOPLAM	35.653,73

ETTN: 92869C00-4402-1EE9-ADEA-86A5C4C44FD3

MÜŞTERİ BİLGİLERİ

SÖZLEŞME HESAP NO : 1016907919
 TESİSAT NO / TEHL KOD : 4010387923
 MÜŞTERİ NO : 203934564
 MÜŞTERİ ADI / SOYADI : ADANA BİLİM VE TEKNOLOJİ ÜNİVERSİTESİ
 İDARI VE MALİ İŞLER DAİRE BAŞKANLIĞI
 ZİYAPASA YOLU : 0070600644
 VERGİ DAİRESİ - VKN : Çift Terimli Tük Zamanı: T:carethane OG (Orta
 Tüketici) Son Kaynak Tarifesi Serbest
 Tüketicisi
 FAKS ADRESİ : GÜLTEPE MAH. CATALAN CD. NO:201/1 RTÜ
 KAMPUS MERKEZ SAKIÇAM ADANA
 OTOMATİK ÖDEME TALİMATI : YOKTUR
 FATURA DÖNÜŞÜ / TARİHİ : Ağustos 2019 / 31.08.2019 23:59



ENERJİSA FİDANLILAR ELEKTRİK
 PERAKENDE SATIŞ A.Ş.
 Beşiktaş Mah. Beşyaprak Sok. Nispetiye
 Postane Bld. No: 111 Beşiktaş / Beşiktaş
 Kat: 3 Kat: 3 V.D.: 856 035 5451

0856 0366 4310 0015
 921047
 (0216) 579 05 00
 (0216) 579 05 30
 enerjisa.com.tr
 toroslarepsas.enerjisa.com

Fatura Seri No: 3522019006003047

ORTALAMA TÜKETİM (kWh/gün)



TÜKETİM BİLGİLERİ VE BEDELLERİ

ENDÜKSİYONLU	KİMLİKLER	SON ÜÇÜNCÜ	1 KİMLİK
Tak Zamanı			33,492
Gündüz	11,338	34,368	23,030
Puani	1,856	5,983	4,127
Gece	2,632	8,967	6,335
Endüstri	0,388	1,244	0,846
Kapasite	0,375	1,386	1,011

ENERJİ BİLGİLERİ	TÜKETİM	KİMLİK / YAT	BEDEL (TL)
Enerji Tük. Bed. (ETB)	210.999,600	0,59036900	124.567,62
ENERJİ TÜKETİM TOPLAM	210.999,600		124.567,62
Güç	1.450,000	3,06255500	4.440,70
SİSTEM KUL. TOPLAM			4.440,70
TOPLAM			129.008,32

GİZET BİLGİLERİ

Enerji Bedelleri Toplamı	129.008,32
Vergi / Fonlar Toplamı	32.462,97
FATURA TUTARI	161.471,29

YALNIZ YUZALTIMISBIRINDOR TULZYETMISBIRTYIRIMDOKUZKIR

Damga Vergisi	1.297,24
ÖDENECEK TUTAR	160.174,05
SON ÖDEME TARİHİ	12.09.2019
ESKİ BORÇ / BAKİYE (TL)	-

Ödemelerinizi zamanında yaptığınız için teşekkür ederiz.

e-Arşiv izni kapsamında elektronik ortamda iletmiştir.

SAYAÇ VE OKUMA BİLGİLERİ

İlk / Son Okuma Tarihi	01.08.2019 / 31.08.2019
Okuma Gün Farkı	31
Sonrakı Okuma Dönemi	09.2019
Sayac Okuma Birimi	T1120030
Akt / End / Kap Sayac Marka / Tip / Seri No	LUNA 67494682
Akım / Gerilim Trafo Oranı	100 / 5 - 31.500 / 100
Sayac Demand Değeri / Anl. Gücü	1.058.400 / 1.450.000
Çarpım	6.300.000
ETSO / EIC	402000047453432Q

TÜKETİMLERİNİZ (kWh/gün)

DÖNEM	TOPLAM	GÜNLÜK ORTALAMA
2018	2.345.225,400 (kWh)	6.643,598 (kWh/gün)
2019	1.705.743,900 (kWh)	7.077,776 (kWh/gün)

MESAJINIZ VAR

VERGİ / FONLAR

BEDEL (TL)

Enerji Fonu	976,97
TRT Payı	1.957,94
Elekt. ve Hvg. Tük. Ver.	4.894,85
KDV %18 (Matrah: 136.840,03 TL)	24.631,21
TOPLAM	32.462,97

ETTN: 0A86FF0C-F102-1EE9-B3AE-8B9C1569C068

MÜŞTERİ BİLGİLERİ

HESAP NO: 1018907919
 NO / TEKİL KOD: 4010837523
 NO: 203934564
 ADI SOYADI: ADANA BİLİM VE TEKNOLOJİ ÜNİVERSİTESİ
 İDARI VE MALİ İŞLER DAİRE BAŞKANLIĞI
 ZİYAPASA V.D. 0079806944
 CİLT (Terim) Tak Zamanlı Ticarethane OG (Orta Gerilim) / Son Kaynak Tarifesi Şerhast
 Tüketici:
 TESISAT ADRESİ: GÜLTEPE MAH. ÇATALAN CD. NO. 201. 1. BTÜ
 KAMPÜS MERKEZİ SARICAM ADANA
 OTOMATİK ÖDEME TALİMATI: YOKTUR
 FATURA DÖNEMİ / TARİHİ: Eylül 2019 / 30.09.2019 21:59



e-Arsiv Fatura

Fatıra Seri No: 3E22019000009369

ENERJİSA TOROSLAR ELEKTRİK
 PEPAK ENDE SATIŞ A.Ş.
 Bahadırpaş Mah. Beşinye Sok. 14. Kat Kat: 14
 Akademi Binası No: 17 / Akademi / Akademi
 Kocayatağan D. 855 036 6431

0856 0366 4510 0015
 921047
 (0216) 579 05 00
 (0216) 579 05 30
 enerjisa.com.tr
 toroslarpepas.enerjisa.com

ORTALAMA TÜKETİM (kWh/gün)



TÜKETİM BİLGİLERİ VE BEDELLERİ

ENDÜKSİYON	ENDÜKSİYON	SON ENDÜKSİYON	FAVİZ
Tak Zaman			35,511
Gündüz	34,368	59,175	24,807
Puanti	5,983	10,194	4,211
Geco	8,967	15,460	6,493
Endüktif	1,244	2,574	1,330
Kapasitif	1,386	1,912	0,526

ENERJİ BİLGİLERİ	LUNA İTİM	KURUM FİYAT	BEDEL (TL)
Enerji Tuk. Bed. (ETB)	223.719,300	0,59036900	132.076,94
ENERJİ TÜKETİMİ TOPLAM	223.719,300		132.076,94
Güc	1.450.000	3,06255500	4.440,70
SİSTEM KUL. TOPLAM			4.440,70
TOPLAM			136.517,64

ÖZET BİLGİLER

Enerji Bedelleri Toplamı	136.517,64
Vergi / Fonlar Toplamı	34.371,77
FATURA TUTARI	170.889,41

YALNIZ YÜZYETMİSBİNSEKİZYÜZSEKSENOKUZTİRKİRSİKİR

Damga Vergisi	1.372,91
ÖDENECEK TUTAR	169.516,50
SON ÖDEME TARİHİ	14.10.2019
ESKİ BORÇ / BAKİYE (TL)	

Odemelerinizi zamanında yaptığınız için teşekkür ederiz.

e-Arsiv izni kapsamında elektronik ortamda iletilmiştir.

SAYAC VE OKUMA BİLGİLERİ

İlk / Son Okuma Tarihi	01.08.2019 / 30.09.2019
Okuma Gün Farkı	30
Sonrakı Okuma Dönemi	10.2019
Sayac Okuma Birimi	T1120030
Akt / End / Kap Sayac Marka / Tip / Seri No	LUNA/6749482
Akım Gerilim Trafo Oranı	100 / 5 31.500 / 100
Sayac Demand Değeri / Anl Gücü	1.033.200 / 1.450.000
Çarpan	6.300.000
ETSO / EIC	40Z000047453442Q

TÜKETİMLERİNİZ (kWh/gün)

DÖNEM	TOPLAM	GÜNLÜK ORTALAMA
2018	2.345.225,400 (kWh)	5.643,698 (kWh/gün)
2019	1.929.463,200 (kWh)	7.119,790 (kWh/gün)


MESAJINIZ VAR

VERGİ / FONLAR

VERGİ / FONLAR	BEDEL (TL)
Enerji Fonu	1.037,99
TRT Payı	2.075,97
Elekt. ve Hvg. Tuk. Ver	5.189,93
KDV %18 (Matrah: 144.821,53 TL)	26.067,88
TOPLAM	34.371,77

ETTN: 0AB6F45F-EC02-1EE9-B9B8-69DFB920C542

Appendix 2 : Suitable Areas and Layout Information with a Map





GENEL YERLEŞİM PLANI



KAMPÜS ALANI



Google earth

YERLEŞİM BİLGİLERİ

1. Kullanılan Panel: 400W Mono
- 2646 adet
2. Toplam Güç: 1058,40 kWp
800,00 kWp
3. Kullanılan İnverter: 100 kW
- 8 adet

ABTÜ GES - ÇATI

GENEL YERLEŞİM PLANI

Appendix 3 : Price Offer from ADAME for Budget Analysis.

İş Türü	No	Açıklama	Miktar	Birim
MEKANİK	TAŞIYICI SİSTEM ve BAĞLANTI PARÇALARI			
	1	Taşıyıcı Sistem Profil ve Aparatları(Alüminyum)	8,8	ton
	2	Taşıyıcı Sistem Profil ve Aparatları(Çelik)	460,0	ton
	3	Panel Klempleri ve Cıvatalar	1	set
ELEKTRİK	SOLAR PANEL - (ANKARA SOLAR)			
	1	Güneş Paneli - 400 Wp Mono Perc	9504,00	kW
	İNVERTER - (HUAWEİ)			
	2	Inverter - SUN2000 100 KTL-M1	77	adet
	SAHA PANOLARI (ALTINSOY, VERA)			
	3	Ana Toplama Panosu	8	adet
	4	Mevcut Pano Tadilatı	1	adet
	DC VE AC KABLOLAR (HELUKABEL, HES, PAMUKKALE, ÖZNUR)			
	5	1x6 mm2 PV1-F	161280	metre
	6	4x150 mm2 NAYY	4488	metre
	7	4x240 mm2 NYN	394	metre
	8	1x95 mm2 XLPE AL	10000	metre
	8	Ag Kablo Başlıkları, Makaron, Kablo yüzüğü	8	set
	HABERLEŞME VE İZLEME SİSTEMİ (ENDOKS, HUAWEİ)			
	9	Scada Sistemi	1	set
	10	Haberleşme Sistemi ve Uzaktan İzleme	1	set
	TOPRAKLAMA SİSTEMİ (RADSAN)			
	11	Topraklama Sistemi (Topraklama iletkeni ve kazıkları)	8	set
	SARF MALZEMELER			
	12	MultiContact	3080	adet
	13	Kablo Kanalı ve Tavaşı	8	set
	14	Uyarı İkaz İşareti ve Levhalar	8	set
	KURULUM ve İŞÇİLİK			
	15	İş Makinaları	1	set
	16	Nakliyeler	1	set
	17	Şantiye Gideri	1	set
	18	Mekanik İşçilik	1	set
	19	Elektrik İşçiliği	1	set
Toplam :			5.172.000,00 \$	
KDV :			930.960,00 \$	
G Toplam :			6.102.960,00 \$	
Birim Fiyat :			544,2 \$	

* Teşvik Kapsamındaki Kalemler İçin KDV Uygulanmayacaktır.

* Liste Proje Onayından Sonra Revize Edilecektir.

* Resmi Kurum Harçları Teklif Kapsamı Dışındadır.

* Trafodan Sonraki Malzeme ve İşlemler Dahil Değildir.

* Anahtar Teslim Toplam Fiyattır.

Appendix 4 : Simulation Summary





Annual Production Report produced by sureyya algan

Design 1 abtu, adana bilim ve teknoloji Üniversitesi

Report	
Project Name	abtu
Project Description	1
Project Address	adana bilim ve teknoloji Üniversitesi
Prepared By	sureyya algan sureyyaalgan7@gmail.com

System Metrics	
Design	Design 1
Module DC Nameplate	9.50 MW
Inverter AC Nameplate	7.70 MW Load Ratio: 1.23
Annual Production	9,489 GWh
Performance Ratio	79.2%
kWh/kWp	998.4
Weather Dataset	TMV, 10km Grid, meteonorm (meteonorm)
Simulator Version	8df3ba8977-b5fd44241f-c7eec90fb7-0331dd75ba



⚡ Annual Production

	Description	Output	% Delta
Irradiance (kWh/m²)	Annual Global Horizontal Irradiance	1,609.6	
	POA Irradiance	1,260.6	-21.7%
	Shaded Irradiance	1,211.9	-3.9%
	Irradiance after Reflection	1,148.9	-5.2%
	Irradiance after Soiling	1,125.9	-2.0%
	Total Collector Irradiance	1,125.9	0.0%
Energy (kWh)	Nameplate	10,700,243.8	
	Output at Irradiance Levels	10,518,143.3	-1.7%
	Output at Cell Temperature Derate	10,053,860.1	-4.4%
	Output After Mismatch	9,725,192.1	-3.3%
	Optimal DC Output	9,673,077.6	-0.5%
	Constrained DC Output	9,672,148.1	0.0%
	Inverter Output	9,536,726.1	-1.4%
	Energy to Grid	9,489,042.4	-0.5%
Temperature Metrics			
	Avg. Operating Ambient Temp		21.7 °C
	Avg. Operating Cell Temp		27.9 °C
Simulation Metrics			
	Operating Hours	4620	
	Solved Hours	4620	

🏠 Condition Set

Description	Condition Set 1											
Weather Dataset	TMY, 10km Grid, meteonorm (meteonorm)											
Solar Angle Location	Meteo Lat/Lng											
Transposition Model	Perez Model											
Temperature Model	Sandia Model											
Temperature Model Parameters	Rack Type	a	b	Temperature Delta								
	Fixed Tilt	-3.56	-0.075	3°C								
	Flush Mount	-2.81	-0.0455	0°C								
Soiling (%)	J	F	M	A	M	J	J	A	S	O	N	D
	2	2	2	2	2	2	2	2	2	2	2	2
Irradiation Variance	5%											
Cell Temperature Spread	4° C											
Module Binning Range	-2.5% to 2.5%											
AC System Derate	0.50%											
Module Characterizations	Module	Uploaded By		Characterization								
	AE400M6-72 (2020) (AE Solar)	Folsom Labs		Spec Sheet Characterization, PAN								
Component Characterizations	Device	Uploaded By		Characterization								
	SUN2000-100KTL-M1 (380/400) (Huawei)	Folsom Labs		Spec Sheet								

📦 Components

Component	Name	Count
Inverters	SUN2000-100KTL-M1 (380/400) (Huawei)	77 (7.70 MW)
Strings	10 AWG (Copper)	1,232 (229,165.3 m)
Module	AE Solar, AE400M6-72 (2020) (400W)	23,760 (9.50 MW)

🔌 Wiring Zones

Description	Combiner Poles	String Size	Stringing Strategy
Wiring Zone	12	6-20	Along Racking

Field Segments									
Description	Racking	Orientation	Tilt	Azimuth	Intrarow Spacing	Frame Size	Frames	Modules	Power
A1	Fixed Tilt	Landscape (Horizontal)	26°	0.929039°	0.6 m	1x1	12,469	12,469	4.99 MW
A2	Fixed Tilt	Landscape (Horizontal)	26°	0.929039°	0.6 m	1x1	8,649	8,649	3.46 MW
B1	Fixed Tilt	Landscape (Horizontal)	26°	136.14576283817507°	1.0 m	1x1	20	20	8.00 kW
B6	Fixed Tilt	Landscape (Horizontal)	26°	136.146°	1.0 m	1x1	20	20	8.00 kW
B2	Fixed Tilt	Landscape (Horizontal)	26°	136.146°	1.0 m	1x1	20	20	8.00 kW
B3	Fixed Tilt	Landscape (Horizontal)	26°	136.146°	1.0 m	1x1	20	20	8.00 kW
B4	Fixed Tilt	Landscape (Horizontal)	26°	136.146°	1.0 m	1x1	20	20	8.00 kW
B5	Fixed Tilt	Landscape (Horizontal)	26°	136.146°	1.0 m	1x1	20	20	8.00 kW
B7	Fixed Tilt	Landscape (Horizontal)	26°	315.0035603190495°	0.8 m	1x1	279	279	111.6 kW
C1	Fixed Tilt	Landscape (Horizontal)	26°	314.585°	0.9 m	1x1	875	875	350.0 kW
D1	Fixed Tilt	Landscape (Horizontal)	26°	314.585°	0.8 m	1x1	255	255	102.0 kW
E1	Fixed Tilt	Landscape (Horizontal)	26°	135°	1.1 m	1x1	547	547	218.8 kW
E2	Fixed Tilt	Landscape (Horizontal)	26°	135°	1.4 m	1x1	123	123	49.2 kW
E3	Fixed Tilt	Landscape (Horizontal)	26°	135°	1.0 m	1x1	311	311	124.4 kW
E4	Fixed Tilt	Landscape (Horizontal)	26°	135°	1.2 m	1x1	132	132	52.8 kW

Detailed Layout

